



Customer Information

809 N. Broadway Milwaukee, WI 53202-3617 414-286-8211

EROSION CONTROL CHECK SHEET

PROPERTY ADDRESS _____

INSPECTOR _____

Permit Number _____

	Date									
Silt Fence										
Fence fabric overlapped										
Based trenched 4"										
Maximum 8' post spacing										
Fabric properly installed										
Fence ends turned upward										
Maximum 9" storage height										
Tracking Pad										
Pad in place										
Pad adequately maintained										
Pad meets minimum standards										
No street tracking										
Inlet Protection										
Inlet protection in place										
Inlet protection maintained										
Inlet protection area swept										
Straw Bales										
Bales properly installed/staked										
Bales in good condition										
Ground Cover										
Ground cover in place										
Ground cover maintained										
Storm Event										
Next day sediment cleanup										
All erosion control checked										

Note:

- * Install all erosion measures before beginning any land-disturbing activity
- * Inspect erosion control measures after each rain of 1/2 inch or more and at least once a week
- * Make repairs as needed.
- * Provide this report of erosion control inspections to construction inspector.
- * Keep copy of erosion control plan at worksite.
- * Failure to comply with these conditions may result in a stop-work order or citation from construction inspector.