

Results below include additional monitoring beyond what is required, and therefore some summary statistics may differ from what must be reported in our Consumer Confidence Report. These samples were analyzed by an external laboratory in 2021.

General Chemistry	Regulatory		Average	Min	Max	Units***
	Limit*	Detected**				
Alkalinity, Total	---	Yes	97.0	96.1	97.9	mg/L as CaCO ₃
Bromide	---	Yes	0.02	0.02	0.02	mg/L
Chlorate	---	Yes	270.0	270.0	270.0	ug/L
Chloride	250	Yes	15.0	15.0	15.0	mg/L
Chlorite	1000	Yes	7.3	7.1	7.5	ug/L
Color (Apparent)	15	No	5.0	5.0	5.0	Pt/Co units
Color (True)	15	No	5.0	5.0	5.0	Pt/Co units
Cyanide, Total	0.2	Yes	0.004	0.003	0.004	mg/L
Fluoride	4	Yes	0.57	0.50	0.63	mg/L
Hardness, Total	---	Yes	130	130	130	mg/L as CaCO ₃
Nitrate, as N	10	Yes	0.36	0.32	0.39	mg/L
Nitrite, as N	1	No	0.003	0.003	0.003	mg/L
Nitrogen, Ammonia	---	Yes	0.13	0.05	0.21	mg/L
Perchlorate	---	Yes	0.20	0.20	0.20	ug/L
pH	6.5-8.5	Yes	7.70	7.70	7.70	pH units
Phosphate, Ortho	---	Yes	0.740	0.580	0.900	mg P/L
Phosphorus	---	Yes	0.772	0.641	0.903	mg/L
Solids, Suspended	---	No	25	25	25	mg/L
Solids, Total	---	Yes	210	200	220	mg/L
Sulfate	250	Yes	25	24	25	mg/L
Total Organic Carbon (TOC)	0	Yes	1.41	0.50	1.64	mg/l
Turbidity	---	Yes	0.3	0.1	0.4	NTU
Disinfection By-Products						
Bromate	0.01	Yes	0.61	0.30	1.30	ug/L
Bromochloroacetic acid	---	Yes	0.40	0.30	0.70	ug/L
Bromochloroacetonitrile	---	Yes	0.01	0.01	0.01	ug/L
Bromodichloroacetic acid	---	Yes	0.91	0.50	1.50	ug/L
Bromodichloromethane		Yes	0.45	0.30	1.10	ug/L
Bromoform		Yes	0.84	0.70	1.60	ug/L
Chlorodibromoacetic acid	---	Yes	2.95	1.80	4.90	ug/L
Chloroform		Yes	0.41	0.30	0.70	ug/L
Chloropicrin	---	Yes	0.73	0.70	1.00	ug/L
Dibromoacetic acid	---	Yes	2.58	1.20	5.20	ug/L
Dibromoacetonitrile	---	Yes	0.52	0.50	0.79	ug/L
Dibromochloromethane		Yes	0.60	0.60	0.80	ug/L
Dichloroacetic acid	---	Yes	0.42	0.30	1.10	ug/L
Dichloroacetonitrile	---	Yes	2.13	0.40	3.80	ug/L
Haloacetic Acids 5	60	Yes	1.25	0.70	3.00	ug/L
Monobromoacetic acid	---	Yes	0.50	0.50	0.93	ug/L
Monochloroacetic acid	---	Yes	1.95	1.50	3.80	ug/L
Tribromoacetic acid	---	No	0.50	0.50	0.50	ug/L

2021 Entry Point Water Quality

Trichloroacetic acid	---	Yes	1.50	1.50	1.50	ug/L
Trichloroacetoneitrile	---	No	1.20	1.20	1.20	ug/L
Total Trihalomethanes		No	0.81	0.70	1.60	ug/L

Aldehydes

Acetaldehyde	---	No	5.2	5.2	5.2	ug/L
Benzaldehyde	---	No	5	5	5	ug/L
Butanal	---	Yes	5	5	5	ug/L
Crotonaldehyde	---	No	5	5	5	ug/L
Cyclohexanone	---	No	5	5	5	ug/L
Decanal	---	No	5	5	5	ug/L
Formaldehyde	---	Yes	5	5	5	ug/L
Glyoxal	---	No	5	5	5	ug/L
Heptanal	---	No	5	5	5	ug/L
Hexanal	---	Yes	5	5	5	ug/L
Methyl glyoxal	---	No	5	5	5	ug/L
Nonanal	---	No	5	5	5	ug/L
Octanal	---	No	5	5	5	ug/L
Pentanal	---	No	5	5	5	ug/L
Propanal	---	No	5	5	5	ug/L

Metals

Aluminum	50-200	Yes	86	52	120	ug/L
Antimony	6	Yes	0.145	0.14	0.15	ug/L
Arsenic	10	No	0.9	0.9	0.9	ug/L
Barium	2000	Yes	19	19	19	ug/L
Beryllium	4	No	0.08	0.08	0.08	ug/L
Boron	---	Yes	23.5	23	24	ug/L
Cadmium	5	No	0.1	0.1	0.1	ug/L
Calcium	---	Yes	33.5	33	34	mg/L
Cerium	---	No	0.1	0.1	0.1	ug/L
Cesium	---	No	0.1	0.1	0.1	ug/L
Chromium	100	Yes	0.4	0.3	0.5	ug/L
Chromium, Hexavalent	---	Yes	0.16875	0.16	0.19	ug/L
Cobalt	---	No	0.13	0.13	0.13	ug/L
Copper	1300	Yes	0.9	0.6	1.2	ug/L
Dysprosium	---	No	0.1	0.1	0.1	ug/L
Erbium	---	No	0.1	0.1	0.1	ug/L
Europium	---	No	0.1	0.1	0.1	ug/L
Gadolinium	---	No	0.1	0.1	0.1	ug/L
Gallium	---	Yes	0.3	0.3	0.3	ug/L
Germanium	---	No	0.1	0.1	0.1	ug/L
Gold	---	Yes	0.25	0.2	0.3	ug/L
Hafnium	---	No	0.1	0.1	0.1	ug/L
Holmium	---	No	0.1	0.1	0.1	ug/L
Iridium	---	No	0.1	0.1	0.1	ug/L
Iron	0.3	No	0	0	0	mg/L
Lanthanum	---	No	0.1	0.1	0.1	ug/L
Lead	15	Yes	0.1	0.1	0.1	ug/L
Lithium	---	Yes	2.2	2.2	2.2	ug/L

2021 Entry Point Water Quality

Lutetium	---	No	0.1	0.1	0.1	ug/L
Magnesium	---	Yes	12	12	12	mg/L
Manganese	50	No	0.2	0.2	0.2	ug/L
Mercury	2	No	0.06	0.06	0.06	ug/L
Molybdenum	---	Yes	0.95	0.95	0.95	ug/L
Neodymium	---	No	0.1	0.1	0.1	ug/L
Nickel	---	Yes	0.3	0.3	0.3	ug/L
Niobium	---	No	0.1	0.1	0.1	ug/L
Osmium	---	Yes	0.9	0.9	0.9	ug/L
Palladium	---	No	0.1	0.1	0.1	ug/L
Phosphorus	---	Yes	730	580	880	ug/L
Platinum	---	No	0.1	0.1	0.1	ug/L
Potassium	---	Yes	1.5	1.5	1.5	mg/L
Praseodymium	---	No	0.1	0.1	0.1	ug/L
Rhenium	---	No	0.1	0.1	0.1	ug/L
Rhodium	---	No	0.1	0.1	0.1	ug/L
Rubidium	---	Yes	1	1	1	ug/L
Ruthenium	---	No	0.1	0.1	0.1	ug/L
Samarium	---	No	0.1	0.1	0.1	ug/L
Selenium	50	No	2	2	2	ug/L
Silica, Total	---	Yes	2.4	2.2	2.6	mg/L
Silver	100	No	0.13	0.13	0.13	ug/L
Sodium	---	Yes	9.8	9.8	9.8	mg/L
Strontium	---	Yes	110	110	110	ug/L
Tellurium	---	No	0.1	0.1	0.1	ug/L
Thallium	2	No	0.16	0.16	0.16	ug/L
Thorium	---	No	0.2	0.2	0.2	ug/L
Thulium	---	No	0.1	0.1	0.1	ug/L
Tin	---	No	0.1	0.1	0.1	ug/L
Titanium	---	Yes	0.77	0.7	0.84	ug/L
Tungsten	---	No	0.1	0.1	0.1	ug/L
Uranium	30	Yes	0.29	0.28	0.3	ug/L
Vanadium	---	Yes	0.3	0.3	0.3	ug/L
Ytterbium	---	No	0.1	0.1	0.1	ug/L
Zinc	5000	No	2.3	2.3	2.3	ug/L
Zirconium	---	No	0.1	0.1	0.1	ug/L

Nitrosamines

N-Nitrosodiethylamine (NDEA)	---	No	2	2	2	ng/L
N-Nitrosodimethylamine (NDMA)	---	No	2	2	2	ng/L
N-Nitrosodi-N-butylamine (NDBA)	---	No	2	2	2	ng/L
N-Nitrosodi-N-propylamine (NDPA)	---	No	2	2	2	ng/L
N-Nitrosodiphenylamine (NDPhA)	---	No	20	20	20	ng/L
N-Nitrosomethylethylamine (NMEA)	---	No	2	2	2	ng/L
N-Nitrosomorpholine (NMOR)	---	No	2	2	2	ng/L
N-Nitrosopiperidine (NPIP)	---	No	2	2	2	ng/L
N-Nitrosopyrrolidine (NPYR)	---	No	2	2	2	ng/L

Perfluorinated Alkyl Substances (PFAS)

10:2 Fluorotelomer sulfonic acid (10:2 FTS)	---	No	1.5	1.5	1.5	ng/L
11Cl-PF3OUdS/F-53B Minor	---	No	1.3	1.3	1.3	ng/L
4:2 Fluorotelomer sulfonic acid (4:2)	---	No	0.7	0.7	0.7	ng/L
6:2 Fluorotelomer sulfonic acid (6:2)	---	No	0.7	0.7	0.7	ng/L
8:2 Fluorotelomer sulfonic acid (8:2)	---	No	0.7	0.7	0.7	ng/L
9Cl-PF3ONS/F-53B Major	---	No	0.7	0.7	0.7	ng/L
ADONA	---	No	0.7	0.7	0.7	ng/L
HFPO-DA/GenX	---	No	1.7	1.7	1.7	ng/L
Nafion Byproduct 1	---	No	5	5	5	ng/L
Nafion Byproduct 2	---	No	5	5	5	ng/L
N-ethyl	---	No	0.7	0.7	0.7	ng/L
N-ethylperfluorooctane sulfonamide	---	No	0.7	0.7	0.7	ng/L
N-ethylperfluorooctane	---	No	0.7	0.7	0.7	ng/L
N-methyl	---	No	0.7	0.7	0.7	ng/L
N-methylperfluorooctane sulfonamide	---	No	0.7	0.7	0.7	ng/L
N-methylperfluorooctane	---	No	0.7	0.7	0.7	ng/L
Nonafluoro-3,6-dioxaheptanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluoro(3,5,7,9-tetraoxadecanoic)	---	No	5	5	5	ng/L
Perfluoro(3,5,7-trioxaoctanoic) acid	---	No	5	5	5	ng/L
Perfluoro(3,5-dioxahexanoic) acid	---	No	5	5	5	ng/L
Perfluoro-2-methoxyacetic acid	---	No	5	5	5	ng/L
Perfluoro-3-methoxypropanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluoro-4-isopropoxybutanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluoro-4-methoxybutanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluorobutanesulfonic acid (PFBS)	---	No	0.7	0.7	0.7	ng/L
Perfluorobutanoic acid (PFBA)	---	Yes	1.95	1.8	2.1	ng/L
Perfluorodecanesulfonic acid (PFDS)	---	No	0.7	0.7	0.7	ng/L
Perfluorodecanoic acid (PFDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorododecanesulfonic acid	---	No	1.2	1.2	1.2	ng/L
Perfluorododecanoic acid (PFDoA)	---	No	0.7	0.7	0.7	ng/L
Perfluoroheptanesulfonic acid (PFHpS)	---	No	0.7	0.7	0.7	ng/L
Perfluoroheptanoic acid (PFHpA)	---	Yes	0.95	0.9	1	ng/L
Perfluorohexadecanoic acid (PFHxDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorohexanesulfonic acid (PFHxS)	---	Yes	0.7	0.7	0.7	ng/L
Perfluorohexanoic acid (PFHxA)	---	Yes	1.3	1.3	1.3	ng/L
Perfluorononanesulfonic acid (PFNS)	---	No	0.7	0.7	0.7	ng/L
Perfluorononanoic acid (PFNA)	---	No	0.7	0.7	0.7	ng/L
Perfluorooctane sulfonamide (PFOSA)	---	No	0.7	0.7	0.7	ng/L
Perfluorooctanesulfonic acid (PFOS)	---	Yes	2.15	2	2.3	ng/L
Perfluorooctanoic acid (PFOA)	---	Yes	1.9	1.8	2	ng/L
Perfluoropentanesulfonic acid (PFPeS)	---	No	0.7	0.7	0.7	ng/L
Perfluoropentanoic acid (PFPeA)	---	Yes	1.3	1.3	1.3	ng/L
Perfluorotetradecanoic acid (PFTeDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorotridecanoic acid (PFTrDA)	---	No	1.6	1.6	1.6	ng/L
Perfluoroundecanoic acid (PFUnA)	---	No	0.7	0.7	0.7	ng/L
Pharmaceuticals and Personal Care Products						
17alpha-Estradiol	---	No	0.5	0.5	0.5	ng/L

2021 Entry Point Water Quality

17alpha-Ethynyl estradiol	---	No	0.5	0.5	0.5	ng/L
17beta-Estradiol	---	No	0.5	0.5	0.5	ng/L
2,4,6-Trichlorophenol	---	No	0.1	0.1	0.1	ug/L
4-n-Octylphenol	---	No	0.5	0.5	0.5	ug/L
4-tert-Octylphenol	---	No	0.5	0.5	0.5	ug/L
Acesulfame-K	---	Yes	0.02	0.02	0.02	ug/L
Acetaminophen	---	No	0.005	0.005	0.005	ug/L
Acrylamide	---	No	0.5	0.5	0.5	ug/L
Antipyrine	---	No	0.001	0.001	0.001	ug/L
Atenolol	---	No	0.001	0.001	0.001	ug/L
Azithromycin	---	No	0.005	0.005	0.005	ug/L
Bezafibrate	---	No	0.0005	0.0005	0.0005	ug/L
Bisphenol A	---	No	0.1	0.1	0.1	ug/L
Caffeine	---	No	0.05	0.05	0.05	ug/L
Carbadox	---	No	0.005	0.005	0.005	ug/L
Carbamazepine	---	No	0.001	0.001	0.001	ug/L
Chloramphenicol	---	No	0.005	0.005	0.005	ug/L
Chlorotetracycline	---	No	0.05	0.05	0.05	ug/L
cis-Testosterone	---	No	0.1	0.1	0.1	ng/L
Clofibric acid	---	No	0.0005	0.0005	0.0005	ug/L
Cotinine	---	Yes	0.001	0.001	0.001	ug/L
DEET	---	No	0.005	0.005	0.005	ug/L
Dexamethasone	---	No	0.005	0.005	0.005	ug/L
Diazepam	---	No	0.001	0.001	0.001	ug/L
Diclofenac	---	Yes	0.00105	0.0005	0.0016	ug/L
Diethylstilbestrol (DES)	---	No	0.5	0.5	0.5	ng/L
Dilantin	---	No	0.002	0.002	0.002	ug/L
Diltiazem	---	No	0.0001	0.0001	0.0001	ug/L
Erythromycin	---	No	0.001	0.001	0.001	ug/L
Estriol	---	No	0.5	0.5	0.5	ng/L
Estrone	---	No	0.5	0.5	0.5	ng/L
Fluoxetine (Prozac)	---	No	0.001	0.001	0.001	ug/L
Gemfibrozil	---	No	0.0005	0.0005	0.0005	ug/L
Ibuprofen	---	No	0.05	0.05	0.05	ug/L
Iopromide	---	No	0.05	0.05	0.05	ug/L
Levothyroxine (Synthroid)	---	No	0.002	0.002	0.002	ug/L
Lincomycin	---	No	0.0001	0.0001	0.0001	ug/L
Meprobamate	---	No	0.001	0.001	0.001	µg/L
Monensin	---	No	0.001	0.001	0.001	µg/L
Naproxen	---	No	0.002	0.002	0.002	µg/L
Narasin	---	No	0.001	0.001	0.001	µg/L
Nicotine	---	No	0.01	0.01	0.01	µg/L
Nonylphenol, isomer mix	---	Yes	0.6	0.5	0.7	µg/L
Oleandomycin	---	No	0.001	0.001	0.001	µg/L
Paraxanthine	---	No	0.005	0.005	0.005	µg/L
Penicillin G	---	No	0.002	0.002	0.002	µg/L
Penicillin V	---	No	0.002	0.002	0.002	µg/L
Pentachlorophenol	---	No	0.02	0.02	0.02	ug/L

2021 Entry Point Water Quality

Phenylphenol	---	No	0.1	0.1	0.1	ug/L
Prednisone	---	No	0.002	0.002	0.002	ng/L
Primidone	---	No	0.005	0.005	0.005	ug/L
Progesterone	---	No	0.1	0.1	0.1	ug/L
Roxithromycin	---	No	0.001	0.001	0.001	ug/L
Salicylic acid	---	No	0.05	0.05	0.05	ug/L
Salinomycin	---	No	0.0001	0.0001	0.0001	ug/L
Sucralose	---	Yes	0.052	0.047	0.057	ug/L
Sulfadiazine	---	No	0.001	0.001	0.001	ug/L
Sulfadimethoxine	---	No	0.0001	0.0001	0.0001	ug/L
Sulfamethazine	---	No	0.001	0.001	0.001	ug/L
Sulfamethizole	---	No	0.001	0.001	0.001	ug/L
Sulfamethoxazole	---	No	0.001	0.001	0.001	ug/L
Sulfasalazine	---	No	0.005	0.005	0.005	ug/L
Sulfathiazole	---	No	0.001	0.001	0.001	ug/L
Tetrabromobisphenol A	---	No	0.1	0.1	0.1	ug/L
Theobromine	---	No	0.05	0.05	0.05	ng/L
Theophylline	---	No	0.005	0.005	0.005	ug/L
trans-Testosterone	---	No	0.1	0.1	0.1	ug/L
Triclocarban	---	No	0.0005	0.0005	0.0005	ug/L
Triclosan	---	No	0.05	0.05	0.05	ug/L
Trimethoprim	---	No	0.001	0.001	0.001	ug/L
Tris(2-chloroethyl) phosphate	---	No	0.01	0.01	0.01	ug/L
Tris(chloropropyl) phosphate	---	Yes	0.01	0.01	0.01	ug/L
Tylosin	---	No	0.001	0.001	0.001	ug/L
Virginiamycin M1	---	No	0.001	0.001	0.001	ug/L
Semi-Volatile Organic Compounds						
1,2,4,5-Tetrachlorobenzene	---	No	0.06	0.06	0.06	ug/L
1-Methylnaphthalene	---	No	0.02	0.02	0.02	ug/L
1-Naphthol	---	No	0.2	0.2	0.2	ug/L
2,2',3,3',4,4',6-Heptachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',3,3',4,5',6,6'-Octachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',3',4,6-Pentachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',4,4',5,6'-Hexachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',4,4'-Tetrachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,3-Dichlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,4,5-TP (Silvex)	50	No	0.05	0.05	0.05	ug/L
2,4,5-Trichlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,4-D	70	No	0.1	0.1	0.1	ug/L
2,4-Dinitrotoluene	---	No	0.3	0.3	0.3	ug/L
2,6-Dinitrotoluene	---	No	0.06	0.06	0.06	ug/L
2-Chlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2-Methylnaphthalene	---	No	0.02	0.02	0.02	ug/L
3-Hydroxycarbofuran	---	No	0.2	0.2	0.2	ug/L
4,4'-DDD	---	No	0.01	0.01	0.01	ug/L
4,4'-DDE	---	No	0.01	0.01	0.01	ug/L
4,4'-DDT	---	No	0.01	0.01	0.01	ug/L
Acenaphthene	---	No	0.01	0.01	0.01	ug/L

2021 Entry Point Water Quality

Acenaphthylene	---	No	0.01	0.01	0.01	ug/L
Acetochlor	---	No	0.02	0.02	0.02	ug/L
Alachlor	2	No	0.05	0.05	0.05	ug/L
Aldicarb	---	No	0.2	0.2	0.2	ug/L
Aldicarb sulfone	---	No	0.2	0.2	0.2	ug/L
Aldicarb sulfoxide	---	No	0.2	0.2	0.2	ug/L
Aldrin	---	No	0.02	0.02	0.02	ug/L
alpha-Chlordane	---	No	0.01	0.01	0.01	ug/L
alpha-Hexachlorocyclohexane	---	No	0.01	0.01	0.01	ug/L
Ametryn	---	No	0.03	0.03	0.03	ug/L
Anilazine	---	No	0.03	0.03	0.03	ug/L
Anthracene	---	No	0.01	0.01	0.01	ug/L
Aroclor 1016	---	No	0.07	0.07	0.07	ug/L
Aroclor 1221	---	No	0.1	0.1	0.1	ug/L
Aroclor 1232	---	No	0.2	0.2	0.2	ug/L
Aroclor 1242	---	No	0.2	0.2	0.2	ug/L
Aroclor 1248	---	No	0.1	0.1	0.1	ug/L
Aroclor 1254	---	No	0.1	0.1	0.1	ug/L
Aroclor 1260	---	No	0.1	0.1	0.1	ug/L
Aspon	---	No	0.02	0.02	0.02	ug/L
Atraton	---	No	0.03	0.03	0.03	ug/L
Atrazine	3	No	0.03	0.03	0.03	ug/L
Azinphos-ethyl	---	No	0.2	0.2	0.2	ug/L
Azinphos-methyl	---	No	0.07	0.07	0.07	ug/L
Bendiocarb	---	No	0.05	0.05	0.05	ug/L
Benfluralin	---	No	0.02	0.02	0.02	ug/L
Benzo(a)anthracene	---	No	0.01	0.01	0.01	ug/L
Benzo(a)pyrene	0.2	No	0.01	0.01	0.01	ug/L
Benzo(b)fluoranthene	---	No	0.03	0.03	0.03	ug/L
Benzo(g,h,i)perylene	---	No	0.02	0.02	0.02	ug/L
Benzo(k)fluoranthene	---	No	0.01	0.01	0.01	ug/L
beta-BHC	---	No	0.02	0.02	0.02	ug/L
Bolstar	---	No	0.02	0.02	0.02	ug/L
Bromacil	---	No	0	0	0	ug/L
Butachlor	---	No	0.05	0.05	0.05	ug/L
Butylate	---	No	0.01	0.01	0.01	ug/L
Butylbenzylphthalate	---	No	0.2	0.2	0.2	ug/L
Carbaryl	---	No	0.2	0.2	0.2	ug/L
Carbofuran	40	No	0.3	0.3	0.3	ug/L
Carbophenothion	---	No	0.06	0.06	0.06	ug/L
Carboxin	---	No	0.02	0.02	0.02	ug/L
Chlordane	2	No	0.1	0.1	0.1	ug/L
Chlorfenvinphos	---	No	0.06	0.06	0.06	ug/L
Chlorobenzilate	---	No	0.05	0.05	0.05	ug/L
Chloroneb	---	No	0.04	0.04	0.04	ug/L
Chloropropylate	---	No	0.04	0.04	0.04	ug/L
Chlorothalonil	---	No	0.01	0.01	0.01	ug/L
Chlorpropham	---	No	0.05	0.05	0.05	ug/L

2021 Entry Point Water Quality

Chlorpyrifos	---	No	0.03	0.03	0.03	ug/L
Chlorpyrifos methyl	---	No	0.08	0.08	0.08	ug/L
Chrysene	---	No	0.01	0.01	0.01	ug/L
cis-Nonachlor	---	No	0.01	0.01	0.01	ug/L
Clomazone	---	No	0.02	0.02	0.02	ug/L
Clopyralid	---	No	2	2	2	ug/L
Coumaphos	---	No	0.03	0.03	0.03	ug/L
Crotoxyphos	---	No	0.2	0.2	0.2	ug/L
Cyanazine	---	No	0.02	0.02	0.02	ug/L
Cycloate	---	No	0.04	0.04	0.04	ug/L
Dalapon	200	No	0.5	0.5	0.5	ug/L
DCCA	---	No	0.01	0.01	0.01	ug/L
delta-BHC	---	No	0.1	0.1	0.1	ug/L
Demeton O	---	No	0.05	0.05	0.05	ug/L
Demeton S	---	No	0.07	0.07	0.07	ug/L
Desethylatrazine	---	No	0.01	0.01	0.01	ug/L
Desisopropylatrazine	---	No	0.08	0.08	0.08	ug/L
Di(2-ethylhexyl)adipate	400	No	0.6	0.6	0.6	ug/L
Di(2-ethylhexyl)phthalate	6	No	0.6	0.6	0.6	ug/L
Diazinon	---	No	0.02	0.02	0.02	ug/L
Dibenzo(a,h)anthracene	---	No	0.03	0.03	0.03	ug/L
Dicamba	---	No	0.1	0.1	0.1	ug/L
Dichlobenil	---	No	0.02	0.02	0.02	ug/L
Dichlofenthion	---	No	0.02	0.02	0.02	ug/L
Dichloran	---	No	0.04	0.04	0.04	ug/L
Dichlorvos	---	No	0.02	0.02	0.02	ug/L
Dicrotophos	---	No	0.2	0.2	0.2	ug/L
Dieldrin	---	No	0.02	0.02	0.02	ug/L
Diethylphthalate	---	No	0.2	0.2	0.2	ug/L
Dimethoate	---	No	0.2	0.2	0.2	ug/L
Dimethylphthalate	---	No	0.2	0.2	0.2	ug/L
Di-n-butylphthalate	---	No	0.2	0.2	0.2	ug/L
Di-n-octylphthalate	---	No	0.2	0.2	0.2	ug/L
Dinoseb	7	No	0.08	0.08	0.08	ug/L
Dioxathion A	---	No	0.2	0.2	0.2	ug/L
Dioxathion B	---	No	0.3	0.3	0.3	ug/L
Diphenamid	---	No	0.03	0.03	0.03	ug/L
Diquat	20	No	0.3	0.3	0.3	ug/L
Disulfoton	---	No	0.05	0.05	0.05	ug/L
Disulfoton sulfone	---	No	0.05	0.05	0.05	ug/L
Disulfoton sulfoxide	---	No	1	1	1	ug/L
Endosulfan I	---	No	0.02	0.02	0.02	ug/L
Endosulfan II	---	No	0.02	0.02	0.02	ug/L
Endosulfan sulfate	---	No	0.04	0.04	0.04	ug/L
Endothall	100	No	3.7	3.7	3.7	ug/L
Endrin	2	No	0.01	0.01	0.01	ug/L
Endrin aldehyde	---	No	0.03	0.03	0.03	ug/L
E-Phosphamidon	---	No	0.3	0.3	0.3	ug/L

2021 Entry Point Water Quality

EPN	---	No	0.07	0.07	0.07	ug/L
EPTC	---	No	0.02	0.02	0.02	ug/L
Erucylamide	---	No	2	2	2	ug/L
Esfenvalerate	---	No	0.1	0.1	0.1	ug/L
Ethalfuralin	---	No	0.03	0.03	0.03	ug/L
Ethion	---	No	0.02	0.02	0.02	ug/L
Ethofumesate	---	No	0.03	0.03	0.03	ug/L
Ethoprop	---	No	0.07	0.07	0.07	ug/L
Etridiazole	---	No	0.03	0.03	0.03	ug/L
Famphur	---	No	0.02	0.02	0.02	ug/L
Fenamiphos	---	No	0.03	0.03	0.03	ug/L
Fenarimol	---	No	0.3	0.3	0.3	ug/L
Fenitrothion	---	No	0.2	0.2	0.2	ug/L
Fenoxaprop-ethyl	---	No	0.3	0.3	0.3	ug/L
Fensulfothion	---	No	0.1	0.1	0.1	ug/L
Fenthion	---	No	0.03	0.03	0.03	ug/L
Fluazifop-butyl	---	No	0.02	0.02	0.02	ug/L
Fluchloralin	---	No	0.05	0.05	0.05	ug/L
Fluometuron	---	No	0.5	0.5	0.5	ug/L
Fluoranthene	---	No	0.01	0.01	0.01	ug/L
Fluorene	---	No	0.01	0.01	0.01	ug/L
Fluridone	---	No	0.4	0.4	0.4	ug/L
Fonofos	---	No	0.02	0.02	0.02	ug/L
gamma-BHC (Lindane)	0.2	No	0.01	0.01	0.01	ug/L
gamma-Chlordane	---	No	0.01	0.01	0.01	ug/L
Glyphosate	700	No	3.3	3.3	3.3	ug/L
Heptachlor	0.4	No	0.01	0.01	0.01	ug/L
Heptachlor epoxide	0.2	No	0.02	0.02	0.02	ug/L
Hexachlorobenzene	1	No	0.01	0.01	0.01	ug/L
Hexachlorocyclopentadiene	50	No	0.01	0.01	0.01	ug/L
Hexazinone	---	No	0.05	0.05	0.05	ug/L
Indeno(1,2,3-cd)pyrene	---	No	0.02	0.02	0.02	ug/L
Iprodione	---	No	0.2	0.2	0.2	ug/L
Isofenphos	---	No	0.2	0.2	0.2	ug/L
Isophorone	---	No	0.02	0.02	0.02	ug/L
Leptophos	---	No	0.05	0.05	0.05	ug/L
Malathion	---	No	0.01	0.01	0.01	ug/L
Metalaxyl	---	No	0.08	0.08	0.08	ug/L
Methomyl	---	No	0.3	0.3	0.3	ug/L
Methoxychlor	40	No	0.05	0.05	0.05	ug/L
Methyl paraoxon	---	No	0.05	0.05	0.05	ug/L
Methyl parathion	---	No	0.1	0.1	0.1	ug/L
Metolachlor	---	No	0.05	0.05	0.05	ug/L
Metribuzin	---	No	0.06	0.06	0.06	ug/L
Metsulfuron-methyl	---	No	2	2	2	ug/L
Mevinphos	---	No	0.03	0.03	0.03	ug/L
MGK 264 isomer a	---	No	0.01	0.01	0.01	ug/L
MGK 264 isomer b	---	No	0.01	0.01	0.01	ug/L

2021 Entry Point Water Quality

MGK 326	---	No	0.01	0.01	0.01	ug/L
Mirex	---	No	0.09	0.09	0.09	ug/L
Molinate	---	No	0.02	0.02	0.02	ug/L
Monocrotophos	---	No	0.2	0.2	0.2	ug/L
Naled	---	No	0.2	0.2	0.2	ug/L
Napropamide	---	No	0.04	0.04	0.04	ug/L
Norflurazon	---	No	0.2	0.2	0.2	ug/L
Oryzalin	---	No	0.3	0.3	0.3	ug/L
Oxadiazon	---	No	0.01	0.01	0.01	ug/L
Oxamyl	200	No	0.3	0.3	0.3	ug/L
Oxychlorane	---	No	0.02	0.02	0.02	ug/L
Oxyfluorfen	---	No	0.3	0.3	0.3	ug/L
Paraquat	---	No	0.3	0.3	0.3	ug/L
Parathion	---	No	0.2	0.2	0.2	ug/L
Pebulate	---	No	0.02	0.02	0.02	ug/L
Pendimethalin	---	No	0.01	0.01	0.01	ug/L
Pentachlorobenzene	---	No	0.05	0.05	0.05	ug/L
Pentachloronitrobenzene	---	No	0.03	0.03	0.03	ug/L
Permethrin, cis & trans	---	No	0.17	0.17	0.17	ug/L
Phenanthrene	---	No	0.01	0.01	0.01	ug/L
Phorate	---	No	0.03	0.03	0.03	ug/L
Phosmet	---	No	0.09	0.09	0.09	ug/L
Picloram	500	No	0.07	0.07	0.07	ug/L
Profluralin	---	No	0.04	0.04	0.04	ug/L
Prometon	---	No	0.03	0.03	0.03	ug/L
Prometryn	---	No	0.06	0.06	0.06	ug/L
Pronamide	---	No	0.05	0.05	0.05	ug/L
Propachlor	---	No	0.04	0.04	0.04	ug/L
Propanil	---	No	0.03	0.03	0.03	ug/L
Propazine	---	No	0.02	0.02	0.02	ug/L
Propiconazole isomer a	---	No	0.2	0.2	0.2	ug/L
Propiconazole isomer b	---	No	0.2	0.2	0.2	ug/L
Prothiofos	---	No	0.09	0.09	0.09	ug/L
Pyrene	---	No	0.01	0.01	0.01	ug/L
Simazine	4	No	0.03	0.03	0.03	ug/L
Simetryn	---	No	0.02	0.02	0.02	ug/L
Stirofos	---	No	0.02	0.02	0.02	ug/L
Sulfotep	---	No	0.2	0.2	0.2	ug/L
Tebuthiuron	---	No	2	2	2	ug/L
TEPP	---	No	0.3	0.3	0.3	ug/L
Terbacil	---	No	0.12	0.12	0.12	ug/L
Terbufos	---	No	0.03	0.03	0.03	ug/L
Terbutryn	---	No	0.03	0.03	0.03	ug/L
Thiabendazole	---	No	0.3	0.3	0.3	ug/L
Thiobencarb	---	No	0.01	0.01	0.01	ug/L
Thionazin	---	No	0.08	0.08	0.08	ug/L
Toxaphene	3	No	0.4	0.4	0.4	ug/L
trans-Nonachlor	---	No	0.01	0.01	0.01	ug/L

2021 Entry Point Water Quality

Triadimefon	---	No	0.07	0.07	0.07	ug/L
Tribufos	---	No	0.05	0.05	0.05	ug/L
Trichloronate	---	No	0.2	0.2	0.2	ug/L
Tricyclazole	---	No	0.3	0.3	0.3	ug/L
Trifluralin	---	No	0.01	0.01	0.01	ug/L
Vernolate	---	No	0.03	0.03	0.03	ug/L
Vinclozolin	---	No	0.08	0.08	0.08	ug/L
Z-Phosphamidon	---	No	0.07	0.07	0.07	ug/L
Volatile Organic Compounds						
1,1,1,2-Tetrachloroethane	---	No	0.3	0.3	0.3	ug/L
1,1,1-Trichloroethane	200	No	0.2	0.2	0.2	ug/L
1,1,2,2-Tetrachloroethane	---	No	0.2	0.2	0.2	ug/L
1,1,2-Trichloro-1,2,2-trifluoroethane	---	No	0.3	0.3	0.3	ug/L
1,1,2-Trichloroethane	5	No	0.2	0.2	0.2	ug/L
1,1-Dichloroethane	---	No	0.1	0.1	0.1	ug/L
1,1-Dichloroethylene	7	No	0.2	0.2	0.2	ug/L
1,1-Dichloropropanone	---	Yes	1.6	1.6	1.6	ug/L
1,1-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trichlorobenzene	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trichloropropane	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L
1,2,4-Trichlorobenzene	70	No	0.2	0.2	0.2	ug/L
1,2,4-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L
1,2-Dibromo-3-chloropropane (DBCP)		No	0.01	0.01	0.01	ug/L
1,2-Dibromoethane (EDB)		No	0.01	0.01	0.01	ug/L
1,2-Dichlorobenzene	600	No	0.2	0.2	0.2	ug/L
1,2-Dichloroethane	5	No	0.2	0.2	0.2	ug/L
1,2-Dichloropropane	5	No	0.2	0.2	0.2	ug/L
1,2-Xylene	---	No	0.2	0.2	0.2	ug/L
1,3 + 1,4-Xylene	---	No	0.5	0.5	0.5	ug/L
1,3,5-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L
1,3-Butadiene	---	No	0.5	0.5	0.5	ug/L
1,3-Dichlorobenzene	---	No	0.1	0.1	0.1	ug/L
1,3-Dichloropropane	---	No	0.1	0.1	0.1	ug/L
1,3-Dichloropropylene, cis & trans	---	No	0.5	0.5	0.5	ug/L
1,4-Dichlorobenzene	75	No	0.2	0.2	0.2	ug/L
1,4-Dioxane	---	No	2	2	2	ug/L
1-Chlorobutane	---	No	0.7	0.7	0.7	ug/L
2,2-Dichloropropane	---	No	0.2	0.2	0.2	ug/L
2,3,7,8-TCDD	0	No	5	5	5	pg/L
2-Butanone (MEK)	---	No	2	2	2	ug/L
2-Chlorotoluene	---	No	0.1	0.1	0.1	ug/L
2-Hexanone	---	No	1.2	1.2	1.2	ug/L
2-Nitropropane	---	No	0.9	0.9	0.9	ug/L
4-Chlorotoluene	---	No	0.2	0.2	0.2	ug/L
4-Isopropyltoluene	---	No	0.2	0.2	0.2	ug/L
4-Methyl-2-pentanone (MIBK)	---	No	1.5	1.5	1.5	ug/L
Acetone	---	Yes	2.15	2	2.3	ug/L

2021 Entry Point Water Quality

Acrylonitrile	---	No	0.9	0.9	0.9	ug/L
Allyl chloride	---	No	1.1	1.1	1.1	ug/L
Benzene	5	No	0.2	0.2	0.2	ug/L
Benzyl chloride	---	No	0.4	0.4	0.4	ug/L
Bromobenzene	---	No	0.1	0.1	0.1	ug/L
Bromochloromethane	---	No	0.2	0.2	0.2	ug/L
Bromodichloromethane	---	Yes	3.0	1.8	4.9	ug/L
Bromoform	---	Yes	0.4	0.3	0.7	ug/L
Bromomethane	---	No	0.4	0.4	0.4	ug/L
Carbon disulfide	---	No	1	1	1	ug/L
Carbon tetrachloride	5	No	0.1	0.1	0.1	ug/L
Chloroacetonitrile	---	No	2	2	2	ug/L
Chlorobenzene	100	No	0.2	0.2	0.2	ug/L
Chloroethane	---	No	0.2	0.2	0.2	ug/L
Chloroform	---	Yes	2.6	1.2	5.2	ug/L
Chloromethane	---	No	0.2	0.2	0.2	ug/L
Chloroprene	---	No	0.4	0.4	0.4	ug/L
cis-1,2-Dichloroethylene	70	No	0.2	0.2	0.2	ug/L
cis-1,3-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
Cyclohexanone	---	No	5	5	5	ug/L
Di(2-chloroethyl)ether	---	No	0.8	0.8	0.8	ug/L
Dibromochloromethane	---	Yes	2.1	0.4	3.8	ug/L
Dibromomethane	---	No	0.2	0.2	0.2	ug/L
Dichlorodifluoromethane	---	No	0.3	0.3	0.3	ug/L
Dichloromethane	5	No	0.4	0.4	0.4	ug/L
Diisopropyl ether	---	No	0.5	0.5	0.5	ug/L
Epichlorohydrin	---	No	0.8	0.8	0.8	ug/L
Ethyl acrylate	---	No	0.4	0.4	0.4	ug/L
Ethyl Ether	---	No	0.3	0.3	0.3	ug/L
Ethyl methacrylate	---	No	1	1	1	ug/L
Ethyl tert-butyl ether	---	No	0.4	0.4	0.4	ug/L
Ethylbenzene	700	No	0.2	0.2	0.2	ug/L
Hexachlorobutadiene	---	No	0.2	0.2	0.2	ug/L
Hexachloroethane	---	No	1.1	1.1	1.1	ug/L
Isopropylbenzene	---	No	0.2	0.2	0.2	ug/L
Methacrylonitrile	---	No	1.7	1.7	1.7	ug/L
Methyl iodide	---	No	2	2	2	ug/L
Methylacrylate	---	No	0.8	0.8	0.8	ug/L
Methylmethacrylate	---	No	1	1	1	ug/L
Methyl-t-butyl ether (MTBE)	---	No	0.4	0.4	0.4	ug/L
Naphthalene		No	0.02	0.02	0.02	ug/L
n-Butyl acrylate	---	No	0.5	0.5	0.5	ug/L
n-Butylbenzene	---	No	0.2	0.2	0.2	ug/L
Nitrobenzene	---	No	2	2	2	ug/L
n-Propylbenzene	---	No	0.2	0.2	0.2	ug/L
Pentachloroethane	---	No	1.1	1.1	1.1	ug/L
Propionitrile	---	No	1.3	1.3	1.3	ug/L
sec-Butylbenzene	---	No	0.2	0.2	0.2	ug/L

2021 Entry Point Water Quality

Styrene	100	No	0.2	0.2	0.2	ug/L
tert-Amyl Methyl ether	---	No	0.6	0.6	0.6	ug/L
tert-Butyl alcohol	---	No	0.6	0.6	0.6	ug/L
tert-Butylbenzene	---	No	0.2	0.2	0.2	ug/L
Tetrachloroethylene	5	No	0.2	0.2	0.2	ug/L
Tetrahydrofuran	---	No	1.4	1.4	1.4	ug/L
Toluene	1000	No	0.2	0.2	0.2	ug/L
Total Dichlorobenzene	---	No	0.1	0.1	0.1	ug/L
trans-1,2-Dichloroethylene	100	No	0.2	0.2	0.2	ug/L
trans-1,3-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
trans-1,4-Dichloro-2-butylene	---	No	1.4	1.4	1.4	ug/L
Trichloroethylene	5	No	0.2	0.2	0.2	ug/L
Trichlorofluoromethane	---	No	0.2	0.2	0.2	ug/L
Total Trihalomethanes	80	Yes	7.8	1.0	14.6	ug/L
Vinyl acetate	---	No	2	2	2	ug/L
Vinyl chloride	0.2	No	0.2	0.2	0.2	ug/L
Xylenes, Total	10000	No	0.1	0.1	0.1	ug/L

Brominated Diphenyl Ethers

BDE-1	---	No	6.41	6.41	6.41	pg/L
BDE-10	---	No	0.282	0.282	0.282	pg/L
BDE-100	---	No	0.955	0.955	0.955	pg/L
BDE-105	---	No	2.88	2.88	2.88	pg/L
BDE-116	---	No	3.76	3.76	3.76	pg/L
BDE-119/120	---	No	0	0	0	pg/L
BDE-12	---	No	0.188	0.188	0.188	pg/L
BDE-126	---	No	1.46	1.46	1.46	pg/L
BDE-128/154	---	No	0.659	0.659	0.659	pg/L
BDE-13	---	No	0.176	0.176	0.176	pg/L
BDE-138	---	No	1.07	1.07	1.07	pg/L
BDE-140	---	No	0.701	0.701	0.701	pg/L
BDE-15	---	No	0.233	0.233	0.233	pg/L
BDE-153	---	No	1.22	1.22	1.22	pg/L
BDE-155	---	No	0.346	0.346	0.346	pg/L
BDE-166	---	No	1.88	1.88	1.88	pg/L
BDE-17	---	No	0	0	0	pg/L
BDE-181/177	---	No	1.96	1.96	1.96	pg/L
BDE-183/176	---	No	3.1	3.1	3.1	pg/L
BDE-190/171	---	No	1.89	1.89	1.89	pg/L
BDE-2	---	No	4.11	4.11	4.11	pg/L
BDE-203/200	---	No	5.5	5.5	5.5	pg/L
BDE-206	---	No	8.85	8.85	8.85	pg/L
BDE-207	---	No	5.67	5.67	5.67	pg/L
BDE-208	---	No	4.62	4.62	4.62	pg/L
BDE-209	---	No	190	190	190	pg/L
BDE-25	---	No	0.234	0.234	0.234	pg/L
BDE-28/33	---	No	0.996	0.996	0.996	pg/L
BDE-3	---	No	3.64	3.64	3.64	pg/L
BDE-30	---	No	0.205	0.205	0.205	pg/L

2021 Entry Point Water Quality

BDE-32	---	No	0.156	0.156	0.156	pg/L
BDE-35/21	---	No	0.15	0.15	0.15	pg/L
BDE-37	---	No	0.128	0.128	0.128	pg/L
BDE-47	---	No	10.3	10.3	10.3	pg/L
BDE-49	---	No	0.141	0.141	0.141	pg/L
BDE-66	---	No	0.191	0.191	0.191	pg/L
BDE-7	---	No	0.266	0.266	0.266	pg/L
BDE-71	---	No	0.148	0.148	0.148	pg/L
BDE-75/51	---	No	0.106	0.106	0.106	pg/L
BDE-77	---	No	0.106	0.106	0.106	pg/L
BDE-79	---	No	0.094	0.094	0.094	pg/L
BDE-8/11	---	No	0.197	0.197	0.197	pg/L
BDE-85	---	No	2.26	2.26	2.26	pg/L
BDE-99	---	No	3.61	3.61	3.61	pg/L

*--- = not regulated

**For substance No, the results equal the minimim detection limit (MDL)

***Units

mg/L = milligrams per liter = ppm = parts per million

µg/L = micrograms per liter = ppb = parts per billion

ng/L = nanograms per liter = ppt = parts per trillion

pg/L = picograms per liter = ppq = parts per quadrillion