

Results below include additional monitoring beyond what is required, and therefore some summary statistics may differ from what must be reported in our Consumer Confidence Report. These samples were analyzed by an external laboratory in 2021.

General Chemistry	Regulatory		Average	Min	Max	Units***
	Limit*	Detected**				
Alkalinity, Total	---	Yes	102	102	102	mg/L as CaCO3
Bromide	---	Yes	0.025	0.0072	0.038	ug/L
Chlorate	---	Yes	23.5	4	43	ug/L
Chloride	250	Yes	12.5	12	13	mg/L
Chlorite	1000	Yes	11.5	11	12	ug/L
Color (Apparent)	15	No	5	5	5	Pt/Co units
Color (True)	15	No	5	5	5	Pt/Co units
Cyanide, Total	0.2	Yes	0.003	0.003	0.003	mg/L
Fluoride	4	Yes	0.11	0.11	0.11	mg/L
Hardness, Total	---	Yes	130	130	130	mg/L as CaCO3
Nitrate, as N	10	Yes	0.335	0.32	0.35	mg/L
Nitrite, as N	1	No	0.0035	0.003	0.004	mg/L
Nitrogen, Ammonia	---	Yes	0.045	0.045	0.045	mg/l
Perchlorate	---	Yes	0.1	0.1	0.1	ug/L
pH	6.5-8.5	Yes	8.00	8.00	8.00	pH units
Phosphate, Ortho	---	Yes	0.02	0.02	0.02	mg P/L
Phosphorus	---	Yes	0.02	0.02	0.02	mg/L
Solids, Suspended	---	No	25	25	25	mg/L
Solids, Total	---	Yes	200	200	200	mg/L
Sulfate	250	Yes	21	21	21	mg/L
Total Organic Carbon (TOC)	0	Yes	1.85	1.58	2.14	mg/l
Turbidity	---	Yes	0.2	0.1	0.3	NTU
Aldehydes						
Acetaldehyde	---	No	5.1	5.1	5.1	ug/L
Benzaldehyde	---	No	5	5	5	ug/L
Butanal	---	No	5	5	5	ug/L
Crotonaldehyde	---	No	5	5	5	ug/L
Cyclohexanone	---	No	5	5	5	ug/L
Decanal	---	No	5	5	5	ug/L
Formaldehyde	---	No	5	5	5	ug/L
Glyoxal	---	No	5	5	5	ug/L
Heptanal	---	No	5	5	5	ug/L
Hexanal	---	No	5	5	5	ug/L
Methyl glyoxal	---	No	5	5	5	ug/L
Nonanal	---	No	5	5	5	ug/L
Octanal	---	No	5	5	5	ug/L
Pentanal	---	No	5	5	5	ug/L
Propanal	---	No	5	5	5	ug/L
Metals						
Aluminum	50-200	Yes	3.70	1.50	5.90	ug/L
Antimony	6	Yes	0.17	0.17	0.17	ug/L

2021 Source Water Quality

Arsenic	10	No	0.90	0.90	0.90	ug/L
Barium	2000	Yes	20.00	20.00	20.00	ug/L
Beryllium	4	No	0.08	0.08	0.08	ug/L
Boron	---	Yes	23.00	23.00	23.00	ug/L
Cadmium	5	No	0.10	0.10	0.10	ug/L
Calcium	---	Yes	34.00	34.00	34.00	mg/L
Cerium	---	No	0.10	0.10	0.10	ug/L
Cesium	---	No	0.10	0.10	0.10	ug/L
Chromium	100	Yes	0.40	0.30	0.50	ug/L
Chromium, Hexavalent	0	Yes	0.23	0.21	0.26	ug/L
Cobalt	---	No	0.13	0.13	0.13	ug/L
Copper	1300	Yes	30.00	22.00	38.00	ug/L
Dysprosium	---	No	0.10	0.10	0.10	ug/L
Erbium	---	No	0.10	0.10	0.10	ug/L
Europium	---	No	0.10	0.10	0.10	ug/L
Gadolinium	---	No	0.10	0.10	0.10	ug/L
Gallium	---	Yes	0.30	0.30	0.30	ug/L
Germanium	---	No	0.10	0.10	0.10	ug/L
Gold	---	No	0.20	0.20	0.20	ug/L
Hafnium	---	No	0.10	0.10	0.10	ug/L
Holmium	---	No	0.10	0.10	0.10	ug/L
Iridium	---	No	0.10	0.10	0.10	ug/L
Iron	0.3	No	0.00	0.00	0.00	mg/L
Lanthanum	---	No	0.10	0.10	0.10	ug/L
Lead	15	Yes	0.12	0.09	0.14	ug/L
Lithium	---	Yes	2.30	2.30	2.30	ug/L
Lutetium	---	No	0.10	0.10	0.10	ug/L
Magnesium	---	Yes	12.00	12.00	12.00	mg/L
Manganese	50	Yes	0.45	0.20	0.70	ug/L
Mercury	2	No	0.06	0.06	0.06	ug/L
Molybdenum	---	Yes	0.93	0.90	0.95	ug/L
Neodymium	---	No	0.10	0.10	0.10	ug/L
Nickel	---	Yes	0.25	0.20	0.30	ug/L
Niobium	---	No	0.10	0.10	0.10	ug/L
Osmium	---	Yes	1.10	0.90	1.30	ug/L
Palladium	---	No	0.10	0.10	0.10	ug/L
Phosphorus	---	No	2.00	2.00	2.00	ug/L
Platinum	---	No	0.10	0.10	0.10	ug/L
Potassium	---	Yes	1.50	1.50	1.50	mg/L
Praseodymium	---	No	0.10	0.10	0.10	ug/L
Rhenium	---	No	0.10	0.10	0.10	ug/L
Rhodium	---	No	0.10	0.10	0.10	ug/L
Rubidium	---	Yes	1.10	1.10	1.10	ug/L
Ruthenium	---	No	0.10	0.10	0.10	ug/L
Samarium	---	No	0.10	0.10	0.10	ug/L
Selenium	50	No	2.00	2.00	2.00	ug/L
Silica, Total	---	Yes	2.40	2.30	2.50	mg/L
Silver	100	No	0.13	0.13	0.13	ug/L

2021 Source Water Quality

Sodium	---	Yes	7.80	7.60	8.00	mg/L
Strontium	---	Yes	110.0	110.0	110.0	ug/L
Tellurium	---	No	0.10	0.10	0.10	ug/L
Thallium	2	No	0.16	0.16	0.16	ug/L
Thorium	---	No	0.20	0.20	0.20	ug/L
Thulium	---	No	0.10	0.10	0.10	ug/L
Tin	---	No	0.10	0.10	0.10	ug/L
Titanium	---	No	0.70	0.70	0.70	ug/L
Tungsten	---	No	0.10	0.10	0.10	ug/L
Uranium	30	Yes	0.34	0.34	0.34	ug/L
Vanadium	---	Yes	0.40	0.40	0.40	ug/L
Ytterbium	---	No	0.10	0.10	0.10	ug/L
Zinc	5000	No	2.30	2.30	2.30	ug/L
Zirconium	---	No	0.10	0.10	0.10	ug/L
Nitrosamines						
N-Nitrosodiethylamine (NDEA)	---	No	2	2	2	ng/L
N-Nitrosodimethylamine (NDMA)	---	No	2	2	2	ng/L
N-Nitrosodi-N-butylamine (NDBA)	---	No	2	2	2	ng/L
N-Nitrosodi-N-propylamine (NDPA)	---	No	2	2	2	ng/L
N-Nitrosodiphenylamine (NDPhA)	---	No	20	20	20	ng/L
N-Nitrosomethylethylamine (NMEA)	---	No	2	2	2	ng/L
N-Nitrosomorpholine (NMOR)	---	No	2	2	2	ng/L
N-Nitrosopiperidine (NPIP)	---	No	2	2	2	ng/L
N-Nitrosopyrrolidine (NPYR)	---	No	2	2	2	ng/L
Perfluorinated Alkyl Substances (PFAS)						
10:2 Fluorotelomer sulfonic acid (10:2 FTS)	---	No	1.5	1.5	1.5	ng/L
11Cl-PF3OUdS/F-53B Minor	---	No	1.3	1.3	1.3	ng/L
4:2 Fluorotelomer sulfonic acid (4:2)	---	No	0.7	0.7	0.7	ng/L
6:2 Fluorotelomer sulfonic acid (6:2)	---	No	0.7	0.7	0.7	ng/L
8:2 Fluorotelomer sulfonic acid (8:2)	---	No	0.7	0.7	0.7	ng/L
9Cl-PF3ONS/F-53B Major	---	No	0.7	0.7	0.7	ng/L
ADONA	---	No	0.7	0.7	0.7	ng/L
HFPO-DA/GenX	---	No	1.7	1.7	1.7	ng/L
Nafion Byproduct 1	---	No	5	5	5	ng/L
Nafion Byproduct 2	---	No	5	5	5	ng/L
N-ethyl	---	No	0.7	0.7	0.7	ng/L
N-ethylperfluorooctane sulfonamide	---	No	0.7	0.7	0.7	ng/L
N-ethylperfluorooctane	---	No	0.7	0.7	0.7	ng/L
N-methyl	---	No	0.7	0.7	0.7	ng/L
N-methylperfluorooctane sulfonamide	---	No	0.7	0.7	0.7	ng/L
N-methylperfluorooctane	---	No	0.7	0.7	0.7	ng/L
Nonafluoro-3,6-dioxaheptanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluoro(3,5,7,9-tetraoxadecanoic)	---	No	5	5	5	ng/L
Perfluoro(3,5,7-trioxaoctanoic) acid	---	No	5	5	5	ng/L
Perfluoro(3,5-dioxaheptanoic) acid	---	No	5	5	5	ng/L
Perfluoro-2-methoxyacetic acid	---	No	5	5	5	ng/L
Perfluoro-3-methoxypropanoic acid	---	No	1.7	1.7	1.7	ng/L

2021 Source Water Quality

Perfluoro-4-isopropoxybutanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluoro-4-methoxybutanoic acid	---	No	1.7	1.7	1.7	ng/L
Perfluorobutanesulfonic acid (PFBS)	---	No	0.7	0.7	0.7	ng/L
Perfluorobutanoic acid (PFBA)	---	No	1.7	1.7	1.7	ng/L
Perfluorodecanesulfonic acid (PFDS)	---	No	0.7	0.7	0.7	ng/L
Perfluorodecanoic acid (PFDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorododecanesulfonic acid	---	No	1.2	1.2	1.2	ng/L
Perfluorododecanoic acid (PFDoA)	---	No	0.7	0.7	0.7	ng/L
Perfluoroheptanesulfonic acid (PFHpS)	---	No	0.7	0.7	0.7	ng/L
Perfluoroheptanoic acid (PFHpA)	---	Yes	0.85	0.7	1	ng/L
Perfluorohexadecanoic acid (PFHxDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorohexanesulfonic acid (PFHxS)	---	Yes	0.7	0.7	0.7	ng/L
Perfluorohexanoic acid (PFHxA)	---	Yes	1	0.7	1.3	ng/L
Perfluorononanesulfonic acid (PFNS)	---	No	0.7	0.7	0.7	ng/L
Perfluorononanoic acid (PFNA)	---	No	0.7	0.7	0.7	ng/L
Perfluorooctane sulfonamide (PFOSA)	---	No	0.7	0.7	0.7	ng/L
Perfluorooctanesulfonic acid (PFOS)	---	Yes	1.35	0.7	2	ng/L
Perfluorooctanoic acid (PFOA)	---	Yes	1.35	0.7	2	ng/L
Perfluoropentanesulfonic acid (PFPeS)	---	No	0.7	0.7	0.7	ng/L
Perfluoropentanoic acid (PFPeA)	---	Yes	0.95	0.7	1.2	ng/L
Perfluorotetradecanoic acid (PFTeDA)	---	No	0.7	0.7	0.7	ng/L
Perfluorotridecanoic acid (PFTrDA)	---	No	1.6	1.6	1.6	ng/L
Perfluoroundecanoic acid (PFUnA)	---	No	0.7	0.7	0.7	ng/L

Pharmaceuticals and Personal Care Products

17alpha-Estradiol	---	No	0.5	0.5	0.5	ng/L
17alpha-Ethynyl estradiol	---	No	0.5	0.5	0.5	ng/L
17beta-Estradiol	---	No	0.5	0.5	0.5	ng/L
2,4,6-Trichlorophenol	---	No	0.1	0.1	0.1	ug/L
4-n-Octylphenol	---	No	0.5	0.5	0.5	ug/L
4-tert-Octylphenol	---	No	0.5	0.5	0.5	ug/L
Acesulfame-K	---	Yes	0.095	0.09	0.1	ug/L
Acetaminophen	---	No	0.005	0.005	0.005	ug/L
Acrylamide	---	No	0.5	0.5	0.5	ug/L
Antipyrine	---	No	0.001	0.001	0.001	ug/L
Atenolol	---	No	0.001	0.001	0.001	ug/L
Azithromycin	---	No	0.005	0.005	0.005	ug/L
Bezafibrate	---	No	0.0005	0.0005	0.0005	ug/L
Bisphenol A	---	No	0.1	0.1	0.1	ug/L
Caffeine	---	No	0.05	0.05	0.05	ug/L
Carbadox	---	No	0.005	0.005	0.005	ug/L
Carbamazepine	---	No	0.001	0.001	0.001	ug/L
Chloramphenicol	---	No	0.005	0.005	0.005	ug/L
Chlorotetracycline	---	No	0.05	0.05	0.05	ug/L
cis-Testosterone	---	No	0.1	0.1	0.1	ng/L
Clofibrlic acid	---	No	0.0005	0.0005	0.0005	ug/L
Cotinine	---	Yes	0.0015	0.001	0.002	ug/L
DEET	---	No	0.005	0.005	0.005	ug/L
Dexamethasone	---	No	0.005	0.005	0.005	ug/L

2021 Source Water Quality

Diazepam	---	No	0.001	0.001	0.001	ug/L
Diclofenac	---	No	0.0005	0.0005	0.0005	ug/L
Diethylstilbestrol (DES)	---	No	0.5	0.5	0.5	ng/L
Dilantin	---	No	0.002	0.002	0.002	ug/L
Diltiazem	---	No	0.0001	0.0001	0.0001	ug/L
Erythromycin	---	No	0.001	0.001	0.001	ug/L
Estriol	---	No	0.5	0.5	0.5	ng/L
Estrone	---	No	0.5	0.5	0.5	ng/L
Fluoxetine (Prozac)	---	No	0.001	0.001	0.001	ug/L
Gemfibrozil	---	No	0.0005	0.0005	0.0005	ug/L
Ibuprofen	---	No	0.05	0.05	0.05	ug/L
Iopromide	---	No	0.05	0.05	0.05	ug/L
Levothyroxine (Synthroid)	---	No	0.002	0.002	0.002	ug/L
Lincomycin	---	No	0.0001	0.0001	0.0001	ug/L
Meprobamate	---	No	0.001	0.001	0.001	µg/L
Monensin	---	No	0.001	0.001	0.001	µg/L
Naproxen	---	No	0.002	0.002	0.002	µg/L
Narasin	---	No	0.001	0.001	0.001	µg/L
Nicotine	---	No	0.01	0.01	0.01	µg/L
Nonylphenol, isomer mix	---	No	0.5	0.5	0.5	µg/L
Oleandomycin	---	No	0.001	0.001	0.001	µg/L
Paraxanthine	---	No	0.005	0.005	0.005	µg/L
Penicillin G	---	No	0.002	0.002	0.002	µg/L
Penicillin V	---	No	0.002	0.002	0.002	µg/L
Pentachlorophenol	---	No	0.02	0.02	0.02	ug/L
Phenylphenol	---	No	0.1	0.1	0.1	ug/L
Prednisone	---	No	0.002	0.002	0.002	ng/L
Primidone	---	No	0.005	0.005	0.005	ug/L
Progesterone	---	No	0.1	0.1	0.1	ug/L
Roxithromycin	---	No	0.001	0.001	0.001	ug/L
Salicylic acid	---	No	0.05	0.05	0.05	ug/L
Salinomycin	---	No	0.0001	0.0001	0.0001	ug/L
Sucralose	---	Yes	0.0545	0.053	0.056	ug/L
Sulfadiazine	---	No	0.001	0.001	0.001	ug/L
Sulfadimethoxine	---	No	0.0001	0.0001	0.0001	ug/L
Sulfamethazine	---	No	0.001	0.001	0.001	ug/L
Sulfamethizole	---	No	0.001	0.001	0.001	ug/L
Sulfamethoxazole	---	No	0.001	0.001	0.001	ug/L
Sulfasalazine	---	No	0.005	0.005	0.005	ug/L
Sulfathiazole	---	No	0.001	0.001	0.001	ug/L
Tetrabromobisphenol A	---	No	0.1	0.1	0.1	ug/L
Theobromine	---	No	0.05	0.05	0.05	ng/L
Theophylline	---	No	0.005	0.005	0.005	ug/L
trans-Testosterone	---	No	0.1	0.1	0.1	ug/L
Triclocarban	---	No	0.0005	0.0005	0.0005	ug/L
Triclosan	---	No	0.05	0.05	0.05	ug/L
Trimethoprim	---	No	0.001	0.001	0.001	ug/L
Tris(2-chloroethyl) phosphate	---	No	0.01	0.01	0.01	ug/L

2021 Source Water Quality

Tris(chloropropyl) phosphate	---	Yes	0.01	0.01	0.01	ug/L
Tylosin	---	No	0.001	0.001	0.001	ug/L
Virginiamycin M1	---	No	0.001	0.001	0.001	ug/L
Semi-Volatile Organic Compounds						
1,2,4,5-Tetrachlorobenzene	---	No	0.06	0.06	0.06	ug/L
1-Methylnaphthalene	---	No	0.02	0.02	0.02	ug/L
1-Naphthol	---	No	0.2	0.2	0.2	ug/L
2,2',3,3',4,4',6-Heptachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',3,3',4,5',6,6'-Octachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',3',4,6-Pentachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',4,4',5,6'-Hexachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,2',4,4'-Tetrachlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,3-Dichlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,4,5-TP (Silvex)	50	No	0.05	0.05	0.05	ug/L
2,4,5-Trichlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2,4-D	70	No	0.1	0.1	0.1	ug/L
2,4-Dinitrotoluene	---	No	0.3	0.3	0.3	ug/L
2,6-Dinitrotoluene	---	No	0.06	0.06	0.06	ug/L
2-Chlorobiphenyl	---	No	0.01	0.01	0.01	ug/L
2-Methylnaphthalene	---	No	0.02	0.02	0.02	ug/L
3-Hydroxycarbofuran	---	No	0.2	0.2	0.2	ug/L
4,4'-DDD	---	No	0.01	0.01	0.01	ug/L
4,4'-DDE	---	No	0.01	0.01	0.01	ug/L
4,4'-DDT	---	No	0.01	0.01	0.01	ug/L
Acenaphthene	---	No	0.01	0.01	0.01	ug/L
Acenaphthylene	---	No	0.01	0.01	0.01	ug/L
Acetochlor	---	No	0.02	0.02	0.02	ug/L
Alachlor	2	No	0.05	0.05	0.05	ug/L
Aldicarb	---	No	0.2	0.2	0.2	ug/L
Aldicarb sulfone	---	No	0.2	0.2	0.2	ug/L
Aldicarb sulfoxide	---	No	0.2	0.2	0.2	ug/L
Aldrin	---	No	0.02	0.02	0.02	ug/L
alpha-Chlordane	---	No	0.01	0.01	0.01	ug/L
alpha-Hexachlorocyclohexane	---	No	0.01	0.01	0.01	ug/L
Ametryn	---	No	0.03	0.03	0.03	ug/L
Anilazine	---	No	0.03	0.03	0.03	ug/L
Anthracene	---	No	0.01	0.01	0.01	ug/L
Aroclor 1016	---	No	0.07	0.07	0.07	ug/L
Aroclor 1221	---	No	0.1	0.1	0.1	ug/L
Aroclor 1232	---	No	0.2	0.2	0.2	ug/L
Aroclor 1242	---	No	0.2	0.2	0.2	ug/L
Aroclor 1248	---	No	0.1	0.1	0.1	ug/L
Aroclor 1254	---	No	0.1	0.1	0.1	ug/L
Aroclor 1260	---	No	0.1	0.1	0.1	ug/L
Aspon	---	No	0.02	0.02	0.02	ug/L
Atraton	---	No	0.03	0.03	0.03	ug/L
Atrazine	3	No	0.03	0.03	0.03	ug/L
Azinphos-ethyl	---	No	0.2	0.2	0.2	ug/L

2021 Source Water Quality

Azinphos-methyl	---	No	0.07	0.07	0.07	ug/L
Bendiocarb	---	No	0.05	0.05	0.05	ug/L
Benfluralin	---	No	0.02	0.02	0.02	ug/L
Benzo(a)anthracene	---	No	0.01	0.01	0.01	ug/L
Benzo(a)pyrene	0.2	No	0.01	0.01	0.01	ug/L
Benzo(b)fluoranthene	---	No	0.03	0.03	0.03	ug/L
Benzo(g,h,i)perylene	---	No	0.02	0.02	0.02	ug/L
Benzo(k)fluoranthene	---	No	0.01	0.01	0.01	ug/L
beta-BHC	---	No	0.02	0.02	0.02	ug/L
Bolstar	---	No	0.02	0.02	0.02	ug/L
Bromacil	---	No	0	0	0	ug/L
Butachlor	---	No	0.05	0.05	0.05	ug/L
Butylate	---	No	0.01	0.01	0.01	ug/L
Butylbenzylphthalate	---	No	0.2	0.2	0.2	ug/L
Carbaryl	---	No	0.2	0.2	0.2	ug/L
Carbofuran	40	No	0.3	0.3	0.3	ug/L
Carbophenothion	---	No	0.06	0.06	0.06	ug/L
Carboxin	---	No	0.02	0.02	0.02	ug/L
Chlordane	2	No	0.1	0.1	0.1	ug/L
Chlorfenvinphos	---	No	0.06	0.06	0.06	ug/L
Chlorobenzilate	---	No	0.05	0.05	0.05	ug/L
Chloroneb	---	No	0.04	0.04	0.04	ug/L
Chloropropylate	---	No	0.04	0.04	0.04	ug/L
Chlorothalonil	---	No	0.01	0.01	0.01	ug/L
Chlorpropham	---	No	0.05	0.05	0.05	ug/L
Chlorpyrifos	---	No	0.03	0.03	0.03	ug/L
Chlorpyrifos methyl	---	No	0.08	0.08	0.08	ug/L
Chrysene	---	No	0.01	0.01	0.01	ug/L
cis-Nonachlor	---	No	0.01	0.01	0.01	ug/L
Clomazone	---	No	0.02	0.02	0.02	ug/L
Clopyralid	---	No	2	2	2	ug/L
Coumaphos	---	No	0.03	0.03	0.03	ug/L
Crotoxyphos	---	No	0.2	0.2	0.2	ug/L
Cyanazine	---	No	0.02	0.02	0.02	ug/L
Cycloate	---	No	0.04	0.04	0.04	ug/L
Dalapon	200	No	0.5	0.5	0.5	ug/L
DCPA	---	No	0.01	0.01	0.01	ug/L
delta-BHC	---	No	0.1	0.1	0.1	ug/L
Demeton O	---	No	0.05	0.05	0.05	ug/L
Demeton S	---	No	0.07	0.07	0.07	ug/L
Desethylatrazine	---	No	0.01	0.01	0.01	ug/L
Desisopropylatrazine	---	No	0.08	0.08	0.08	ug/L
Di(2-ethylhexyl)adipate	400	No	0.6	0.6	0.6	ug/L
Di(2-ethylhexyl)phthalate	6	No	0.6	0.6	0.6	ug/L
Diazinon	---	No	0.02	0.02	0.02	ug/L
Dibenzo(a,h)anthracene	---	No	0.03	0.03	0.03	ug/L
Dicamba	---	No	0.1	0.1	0.1	ug/L
Dichlobenil	---	No	0.02	0.02	0.02	ug/L

2021 Source Water Quality

Dichlofenthion	---	No	0.02	0.02	0.02	ug/L
Dichloran	---	No	0.04	0.04	0.04	ug/L
Dichlorvos	---	No	0.02	0.02	0.02	ug/L
Dicrotophos	---	No	0.2	0.2	0.2	ug/L
Dieldrin	---	No	0.02	0.02	0.02	ug/L
Diethylphthalate	---	No	0.2	0.2	0.2	ug/L
Dimethoate	---	No	0.2	0.2	0.2	ug/L
Dimethylphthalate	---	No	0.2	0.2	0.2	ug/L
Di-n-butylphthalate	---	No	0.2	0.2	0.2	ug/L
Di-n-octylphthalate	---	No	0.2	0.2	0.2	ug/L
Dinoseb	7 *	No	0.08	0.08	0.08	ug/L
Dioxathion A	---	No	0.2	0.2	0.2	ug/L
Dioxathion B	---	No	0.3	0.3	0.3	ug/L
Diphenamid	---	No	0.03	0.03	0.03	ug/L
Diquat	20 *	No	0.3	0.3	0.3	ug/L
Disulfoton	---	No	0.05	0.05	0.05	ug/L
Disulfoton sulfone	---	No	0.05	0.05	0.05	ug/L
Disulfoton sulfoxide	---	No	1	1	1	ug/L
Endosulfan I	---	No	0.02	0.02	0.02	ug/L
Endosulfan II	---	No	0.02	0.02	0.02	ug/L
Endosulfan sulfate	---	No	0.04	0.04	0.04	ug/L
Endothall	100	No	3.7	3.7	3.7	ug/L
Endrin	2	No	0.01	0.01	0.01	ug/L
Endrin aldehyde	---	No	0.03	0.03	0.03	ug/L
E-Phosphamidon	---	No	0.3	0.3	0.3	ug/L
EPN	---	No	0.07	0.07	0.07	ug/L
EPTC	---	No	0.02	0.02	0.02	ug/L
Erucylamide	---	No	2	2	2	ug/L
Esfenvalerate	---	No	0.1	0.1	0.1	ug/L
Ethalfuralin	---	No	0.03	0.03	0.03	ug/L
Ethion	---	No	0.02	0.02	0.02	ug/L
Ethofumesate	---	No	0.03	0.03	0.03	ug/L
Ethoprop	---	No	0.07	0.07	0.07	ug/L
Etridiazole	---	No	0.03	0.03	0.03	ug/L
Famphur	---	No	0.02	0.02	0.02	ug/L
Fenamiphos	---	No	0.03	0.03	0.03	ug/L
Fenarimol	---	No	0.3	0.3	0.3	ug/L
Fenitrothion	---	No	0.2	0.2	0.2	ug/L
Fenoxaprop-ethyl	---	No	0.3	0.3	0.3	ug/L
Fensulfothion	---	No	0.1	0.1	0.1	ug/L
Fenthion	---	No	0.03	0.03	0.03	ug/L
Fluazifop-butyl	---	No	0.02	0.02	0.02	ug/L
Fluchloralin	---	No	0.05	0.05	0.05	ug/L
Fluometuron	---	No	0.5	0.5	0.5	ug/L
Fluoranthene	---	No	0.01	0.01	0.01	ug/L
Fluorene	---	No	0.01	0.01	0.01	ug/L
Fluridone	---	No	0.4	0.4	0.4	ug/L
Fonofos	---	No	0.02	0.02	0.02	ug/L

2021 Source Water Quality

gamma-BHC (Lindane)	0.2	No	0.01	0.01	0.01	ug/L
gamma-Chlordane	---	No	0.01	0.01	0.01	ug/L
Glyphosate	700	No	3.3	3.3	3.3	ug/L
Heptachlor	0.4	No	0.01	0.01	0.01	ug/L
Heptachlor epoxide	0.2	No	0.02	0.02	0.02	ug/L
Hexachlorobenzene	1	No	0.01	0.01	0.01	ug/L
Hexachlorocyclopentadiene	50	No	0.01	0.01	0.01	ug/L
Hexazinone	---	No	0.05	0.05	0.05	ug/L
Indeno(1,2,3-cd)pyrene	---	No	0.02	0.02	0.02	ug/L
Iprodione	---	No	0.2	0.2	0.2	ug/L
Isofenphos	---	No	0.2	0.2	0.2	ug/L
Isophorone	---	No	0.02	0.02	0.02	ug/L
Leptophos	---	No	0.05	0.05	0.05	ug/L
Malathion	---	No	0.01	0.01	0.01	ug/L
Metalaxyl	---	No	0.08	0.08	0.08	ug/L
Methomyl	---	No	0.3	0.3	0.3	ug/L
Methoxychlor	40	No	0.05	0.05	0.05	ug/L
Methyl paraoxon	---	No	0.05	0.05	0.05	ug/L
Methyl parathion	---	No	0.1	0.1	0.1	ug/L
Metolachlor	---	No	0.05	0.05	0.05	ug/L
Metribuzin	---	No	0.06	0.06	0.06	ug/L
Metsulfuron-methyl	---	No	2	2	2	ug/L
Mevinphos	---	No	0.03	0.03	0.03	ug/L
MGK 264 isomer a	---	No	0.01	0.01	0.01	ug/L
MGK 264 isomer b	---	No	0.01	0.01	0.01	ug/L
MGK 326	---	No	0.01	0.01	0.01	ug/L
Mirex	---	No	0.09	0.09	0.09	ug/L
Molinate	---	No	0.02	0.02	0.02	ug/L
Monocrotophos	---	No	0.2	0.2	0.2	ug/L
Naled	---	No	0.2	0.2	0.2	ug/L
Napropamide	---	No	0.04	0.04	0.04	ug/L
Norflurazon	---	No	0.2	0.2	0.2	ug/L
Oryzalin	---	No	0.3	0.3	0.3	ug/L
Oxadiazon	---	No	0.01	0.01	0.01	ug/L
Oxamyl	200	No	0.3	0.3	0.3	ug/L
Oxychlordane	---	No	0.02	0.02	0.02	ug/L
Oxyfluorfen	---	No	0.3	0.3	0.3	ug/L
Paraquat	---	No	0.3	0.3	0.3	ug/L
Parathion	---	No	0.2	0.2	0.2	ug/L
Pebulate	---	No	0.02	0.02	0.02	ug/L
Pendimethalin	---	No	0.01	0.01	0.01	ug/L
Pentachlorobenzene	---	No	0.05	0.05	0.05	ug/L
Pentachloronitrobenzene	---	No	0.03	0.03	0.03	ug/L
Permethrin, cis & trans	---	No	0.17	0.17	0.17	ug/L
Phenanthrene	---	No	0.01	0.01	0.01	ug/L
Phorate	---	No	0.03	0.03	0.03	ug/L
Phosmet	---	No	0.09	0.09	0.09	ug/L
Picloram	500	No	0.07	0.07	0.07	ug/L

2021 Source Water Quality

Profluralin	---	No	0.04	0.04	0.04	ug/L
Prometon	---	No	0.03	0.03	0.03	ug/L
Prometryn	---	No	0.06	0.06	0.06	ug/L
Pronamide	---	No	0.05	0.05	0.05	ug/L
Propachlor	---	No	0.04	0.04	0.04	ug/L
Propanil	---	No	0.03	0.03	0.03	ug/L
Propazine	---	No	0.02	0.02	0.02	ug/L
Propiconazole isomer a	---	No	0.2	0.2	0.2	ug/L
Propiconazole isomer b	---	No	0.2	0.2	0.2	ug/L
Prothiofos	---	No	0.09	0.09	0.09	ug/L
Pyrene	---	No	0.01	0.01	0.01	ug/L
Simazine	4	No	0.03	0.03	0.03	ug/L
Simetryn	---	No	0.02	0.02	0.02	ug/L
Stirofos	---	No	0.02	0.02	0.02	ug/L
Sulfotep	---	No	0.2	0.2	0.2	ug/L
Tebuthiuron	---	No	2	2	2	ug/L
TEPP	---	No	0.3	0.3	0.3	ug/L
Terbacil	---	No	0.12	0.12	0.12	ug/L
Terbufos	---	No	0.03	0.03	0.03	ug/L
Terbutryn	---	No	0.03	0.03	0.03	ug/L
Thiabendazole	---	No	0.3	0.3	0.3	ug/L
Thiobencarb	---	No	0.01	0.01	0.01	ug/L
Thionazin	---	No	0.08	0.08	0.08	ug/L
Toxaphene	3	No	0.4	0.4	0.4	ug/L
trans-Nonachlor	---	No	0.01	0.01	0.01	ug/L
Triadimefon	---	No	0.07	0.07	0.07	ug/L
Tribufos	---	No	0.05	0.05	0.05	ug/L
Trichloronate	---	No	0.2	0.2	0.2	ug/L
Tricyclazole	---	No	0.3	0.3	0.3	ug/L
Trifluralin	---	No	0.01	0.01	0.01	ug/L
Vernolate	---	No	0.03	0.03	0.03	ug/L
Vinclozolin	---	No	0.08	0.08	0.08	ug/L
Z-Phosphamidon	---	No	0.07	0.07	0.07	ug/L
Volatile Organic Compounds						
1,1,1,2-Tetrachloroethane	---	No	0.3	0.3	0.3	ug/L
1,1,1-Trichloroethane	200	No	0.2	0.2	0.2	ug/L
1,1,2,2-Tetrachloroethane	---	No	0.2	0.2	0.2	ug/L
1,1,2-Trichloro-1,2,2-trifluoroethane	---	No	0.3	0.3	0.3	ug/L
1,1,2-Trichloroethane	5	No	0.2	0.2	0.2	ug/L
1,1-Dichloroethane	---	No	0.1	0.1	0.1	ug/L
1,1-Dichloroethylene	7	No	0.2	0.2	0.2	ug/L
1,1-Dichloropropanone	---	No	1.6	1.6	1.6	ug/L
1,1-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trichlorobenzene	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trichloropropane	---	No	0.2	0.2	0.2	ug/L
1,2,3-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L
1,2,4-Trichlorobenzene	70	No	0.2	0.2	0.2	ug/L
1,2,4-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L

2021 Source Water Quality

1,2-Dibromo-3-chloropropane (DBCP)		No	0.01	0.01	0.01	ug/L
1,2-Dibromoethane (EDB)		No	0.01	0.01	0.01	ug/L
1,2-Dichlorobenzene	600	No	0.2	0.2	0.2	ug/L
1,2-Dichloroethane	5	No	0.2	0.2	0.2	ug/L
1,2-Dichloropropane	5	No	0.2	0.2	0.2	ug/L
1,2-Xylene	---	No	0.2	0.2	0.2	ug/L
1,3 + 1,4-Xylene	---	No	0.5	0.5	0.5	ug/L
1,3,5-Trimethylbenzene	---	No	0.2	0.2	0.2	ug/L
1,3-Butadiene	---	No	0.5	0.5	0.5	ug/L
1,3-Dichlorobenzene	---	No	0.1	0.1	0.1	ug/L
1,3-Dichloropropane	---	No	0.1	0.1	0.1	ug/L
1,3-Dichloropropylene, cis & trans	---	No	0.5	0.5	0.5	ug/L
1,4-Dichlorobenzene	75	No	0.2	0.2	0.2	ug/L
1,4-Dioxane	---	No	2	2	2	ug/L
1-Chlorobutane	---	No	0.7	0.7	0.7	ug/L
2,2-Dichloropropane	---	No	0.2	0.2	0.2	ug/L
2,3,7,8-TCDD	0	No	5	5	5	pg/L
2-Butanone (MEK)	---	No	2	2	2	ug/L
2-Chlorotoluene	---	No	0.1	0.1	0.1	ug/L
2-Hexanone	---	No	1.2	1.2	1.2	ug/L
2-Nitropropane	---	No	0.9	0.9	0.9	ug/L
4-Chlorotoluene	---	No	0.2	0.2	0.2	ug/L
4-Isopropyltoluene	---	No	0.2	0.2	0.2	ug/L
4-Methyl-2-pentanone (MIBK)	---	No	1.5	1.5	1.5	ug/L
Acetone	---	No	2	2	2	ug/L
Acrylonitrile	---	No	0.9	0.9	0.9	ug/L
Allyl chloride	---	No	1.1	1.1	1.1	ug/L
Benzene	5	No	0.2	0.2	0.2	ug/L
Benzyl chloride	---	No	0.4	0.4	0.4	ug/L
Bromobenzene	---	No	0.1	0.1	0.1	ug/L
Bromochloromethane	---	No	0.2	0.2	0.2	ug/L
Bromodichloromethane	---	Yes	0.85	0.1	1.6	ug/L
Bromoform	---	No	0.2	0.2	0.2	ug/L
Bromomethane	---	No	0.4	0.4	0.4	ug/L
Carbon disulfide	---	No	1	1	1	ug/L
Carbon tetrachloride	5	No	0.1	0.1	0.1	ug/L
Chloroacetonitrile	---	No	2	2	2	ug/L
Chlorobenzene	100	No	0.2	0.2	0.2	ug/L
Chloroethane	---	No	0.2	0.2	0.2	ug/L
Chloroform	---	Yes	0.7	0.2	1.2	ug/L
Chloromethane	---	No	0.2	0.2	0.2	ug/L
Chloroprene	---	No	0.4	0.4	0.4	ug/L
cis-1,2-Dichloroethylene	70	No	0.2	0.2	0.2	ug/L
cis-1,3-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
Cyclohexanone	---	No	5	5	5	ug/L
Di(2-chloroethyl)ether	---	No	0.8	0.8	0.8	ug/L
Dibromochloromethane	---	Yes	0.6	0.1	1.1	ug/L
Dibromomethane	---	No	0.2	0.2	0.2	ug/L

2021 Source Water Quality

Dichlorodifluoromethane	---	No	0.3	0.3	0.3	ug/L
Dichloromethane	5	No	0.4	0.4	0.4	ug/L
Diisopropyl ether	---	No	0.5	0.5	0.5	ug/L
Epichlorohydrin	---	No	0.8	0.8	0.8	ug/L
Ethyl acrylate	---	No	0.4	0.4	0.4	ug/L
Ethyl Ether	---	No	0.3	0.3	0.3	ug/L
Ethyl methacrylate	---	No	1	1	1	ug/L
Ethyl tert-butyl ether	---	No	0.4	0.4	0.4	ug/L
Ethylbenzene	700	No	0.2	0.2	0.2	ug/L
Hexachlorobutadiene	---	No	0.2	0.2	0.2	ug/L
Hexachloroethane	---	No	1.1	1.1	1.1	ug/L
Isopropylbenzene	---	No	0.2	0.2	0.2	ug/L
Methacrylonitrile	---	No	1.7	1.7	1.7	ug/L
Methyl iodide	---	No	2	2	2	ug/L
Methylacrylate	---	No	0.8	0.8	0.8	ug/L
Methylmethacrylate	---	No	1	1	1	ug/L
Methyl-t-butyl ether (MTBE)	---	No	0.4	0.4	0.4	ug/L
Naphthalene		No	0.02	0.02	0.02	ug/L
n-Butyl acrylate	---	No	0.5	0.5	0.5	ug/L
n-Butylbenzene	---	No	0.2	0.2	0.2	ug/L
Nitrobenzene	---	No	2	2	2	ug/L
n-Propylbenzene	---	No	0.2	0.2	0.2	ug/L
Pentachloroethane	---	No	1.1	1.1	1.1	ug/L
Propionitrile	---	No	1.3	1.3	1.3	ug/L
sec-Butylbenzene	---	No	0.2	0.2	0.2	ug/L
Styrene	100	No	0.2	0.2	0.2	ug/L
tert-Amyl Methyl ether	---	No	0.6	0.6	0.6	ug/L
tert-Butyl alcohol	---	No	0.6	0.6	0.6	ug/L
tert-Butylbenzene	---	No	0.2	0.2	0.2	ug/L
Tetrachloroethylene	5	No	0.2	0.2	0.2	ug/L
Tetrahydrofuran	---	No	1.4	1.4	1.4	ug/L
Toluene	1000	No	0.2	0.2	0.2	ug/L
Total Dichlorobenzene	---	No	0.1	0.1	0.1	ug/L
trans-1,2-Dichloroethylene	100	No	0.2	0.2	0.2	ug/L
trans-1,3-Dichloropropylene	---	No	0.2	0.2	0.2	ug/L
trans-1,4-Dichloro-2-butylene	---	No	1.4	1.4	1.4	ug/L
Trichloroethylene	5	No	0.2	0.2	0.2	ug/L
Trichlorofluoromethane	---	No	0.2	0.2	0.2	ug/L
TTHM	80	Yes	2.05	0.20	3.90	ug/L
Vinyl acetate	---	No	2	2	2	ug/L
Vinyl chloride	0.2	No	0.2	0.2	0.2	ug/L
Xylenes, Total	10000	No	0.1	0.1	0.1	ug/L
1,1,1,2-Tetrachloroethane	---	No	0.3	0.3	0.3	ug/L
1,1,1-Trichloroethane	200	No	0.2	0.2	0.2	ug/L
1,1,2,2-Tetrachloroethane	---	No	0.2	0.2	0.2	ug/L
Brominated Diphenyl Ethers						
BDE-1	---	No	6.41	6.41	6.41	pg/L
BDE-10	---	No	0.955	0.955	0.955	pg/L

2021 Source Water Quality

BDE-100	---	No	2.88	2.88	2.88	pg/L
BDE-105	---	No	3.76	3.76	3.76	pg/L
BDE-116	---	No	3.76	3.76	3.76	pg/L
BDE-119/120	---	No	0.702	0.702	0.702	pg/L
BDE-12	---	No	1.46	1.46	1.46	pg/L
BDE-126	---	No	1.46	1.46	1.46	pg/L
BDE-128/154	---	No	0.659	0.659	0.659	pg/L
BDE-13	---	No	1.07	1.07	1.07	pg/L
BDE-138	---	No	1.07	1.07	1.07	pg/L
BDE-140	---	No	0.701	0.701	0.701	pg/L
BDE-15	---	No	0.954	0.954	0.954	pg/L
BDE-153	---	No	0.954	0.954	0.954	pg/L
BDE-155	---	No	1.88	1.88	1.88	pg/L
BDE-166	---	No	1.88	1.88	1.88	pg/L
BDE-17	---	No	1.96	1.96	1.96	pg/L
BDE-181/177	---	No	1.96	1.96	1.96	pg/L
BDE-183/176	---	No	1.89	1.89	1.89	pg/L
BDE-190/171	---	No	4.11	4.11	4.11	pg/L
BDE-2	---	No	5.5	5.5	5.5	pg/L
BDE-203/200	---	No	8.85	8.85	8.85	pg/L
BDE-206	---	No	8.85	8.85	8.85	pg/L
BDE-207	---	No	5.67	5.67	5.67	pg/L
BDE-208	---	No	190	190	190	pg/L
BDE-209	---	No	190	190	190	pg/L
BDE-25	---	No	1.07	1.07	1.07	pg/L
BDE-28/33	---	No	3.64	3.64	3.64	pg/L
BDE-3	---	No	3.64	3.64	3.64	pg/L
BDE-30	---	No	0.205	0.205	0.205	pg/L
BDE-32	---	No	0.156	0.156	0.156	pg/L
BDE-35/21	---	No	0.15	0.15	0.15	pg/L
BDE-37	---	No	12.9	12.9	12.9	pg/L
BDE-47	---	No	12.9	12.9	12.9	pg/L
BDE-49	---	No	0.191	0.191	0.191	pg/L
BDE-66	---	No	0.266	0.266	0.266	pg/L
BDE-7	---	No	0.266	0.266	0.266	pg/L
BDE-71	---	No	0.148	0.148	0.148	pg/L
BDE-75/51	---	No	0.106	0.106	0.106	pg/L
BDE-77	---	No	0.106	0.106	0.106	pg/L
BDE-79	---	No	0.197	0.197	0.197	pg/L
BDE-8/11	---	No	2.26	2.26	2.26	pg/L
BDE-85	---	No	4.52	4.52	4.52	pg/L
BDE-99	---	No	4.52	4.52	4.52	pg/L

*--- = not regulated

**For substance No, the results equal the minimim detection limit (MDL)

***Units

mg/L = milligrams per liter = ppm = parts per million

µg/L = micrograms per liter = ppb = parts per billion

ng/L = nanograms per liter = ppt = parts per trillion

