


5 and 10 Year Main Break Averages

Update: 01/13/2020 CM

MONTH	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	5 YR AVG	10 YR AVG
JAN	118	52	139	211	79	50	66	146	56	30	70	95
FEB	81	29	107	234	71	50	27	63	87	46	55	80
MAR	46	22	61	108	63	22	7	35	80	12	31	46
APR	18	12	20	38	17	12	9	19	34	11	17	19
MAY	10	16	24	111	13	15	14	36	16	17	20	27
JUN	35	38	21	49	24	26	17	20	35	25	25	29
JUL	41	90	29	37	40	34	37	30	46	32	36	42
AUG	69	62	27	34	43	88	71	41	51	67	64	55
SEP	47	35	43	23	25	32	36	26	40	15	30	32
OCT	32	34	29	19	22	25	20	17	34	16	22.4	25
NOV	22	37	25	32	15	22	30	30	41	18	28	27
DEC	28	40	91	34	19	57	43	54	33	27	43	43
TOTALS	547	467	616	930	431	433	377	517	553	316	439	519
Breaks/100Miles	28	24	31	47	22	22	19	26	28	16	22	26



Greenfield Tank OOS

Pressure Dist (18 main breaks within pressure change area, 35 main breaks outside)

Pressure Dist (12 main breaks within pressure change area, 30 main breaks outside)

Howard Plant OOS 2014

Main Break Averages

— 5 YR AVG
 — 10 YR AVG
 — 2019
 — 2020

