

EXHIBIT A TO OFFER TO PURCHASE -- CITY OF MILWAUKEE SCOPE OF WORK

Scope of Work for Property Located at: 2119 N 40th St

Property is: Single Family Duplex **Other** 3 Family

Date: 9/10/2025 OCCUPIED VACANT

City prepared this Scope upon visual inspection only, for limited purpose. City does not warrant content or conclusions, and is not responsible for errors, omissions, or discovery of conditions that are or may constitute defects or concerns

ESSENTIAL REPAIRS. All buyers must complete Essential Repairs and obtain "Essential Repair Verification Form" and provide same to DCD within 180 days of City's deed to buyer in order to get return of performance deposit.

Location	Required Work	Note/Comments	Cost
Entire Building	Structural Violations	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing HVAC	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Permits required. Replace HVAC System including	\$ 10,000.00
	Defective/Missing Plumbing	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Permits required. 1st floor unit bathroom replaced,	\$ 5,000.00
	Defective/Missing Electrical	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Permits required. Restore Electrical Service - All th	\$ 15,000.00
	Defective/Missing Egress	n/a <input checked="" type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing Smoke/CO Alarm	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	\$ 850.00
	Repair Defective Paint (Interior)	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Including plaster and drywall repair - All three units	\$ 12,000.00
	Defective/Missing Roof (Major)	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Repair/ Replace including gutters	\$ 18,000.00
	Missing Window(s)	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Missing Exterior Door(s)	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	\$ 1,700.00
	Other	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Cabinets, millwork	\$ 5,000.00

Lead (Pb) orders from MHD exist and must be completed with other essential repairs.

Essential Repairs: Estimated Cost:* \$ 67,550.00

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

OTHER REPAIRS (Exterior & Interior). Buyer is notified that the following are code violations that must be addressed and are subject to Department of Neighborhood Services (DNS) enforcement.

Exterior Condition Report

Location	Required Work	Note/Comments	Cost
Site	Landscaping	n/a <input type="checkbox"/> Yes <input type="checkbox"/> Self Help	\$
	Steps/Handrails	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> Service steps handrail	\$ 5,000.00
	Service walks	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Fencing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Parking	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Retaining walls	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
Garage		N/A	
	Singles: repair	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Shingles: Roof over existing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Shingles:Tear off & re-roof	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Gutters/downspouts	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	\$
	Flashing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Eaves	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Siding	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Doors	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Windows	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Slab	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Paint	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Electrical	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$

Porches

Roof	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Deck-upper	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Deck-lower	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Steps/handrails	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Front Lower, Replace to code compliance condition \$ 1,500.00
Ceiling	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Guardrails	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Front Upper, Repair to code compliance condition \$ 1,000.00
Structural	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Paint	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

House

Chimney	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles: repair	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles: Roof over existing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles:Tear off & re-roof	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Gutters/downspouts	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Flashing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Eaves	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Siding	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	North dormer \$ 500.00
Storm Doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Prime ("main") Doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	2nd floor porch door \$ 850.00
Storm Windows	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Prime ("main") Windows	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Paint	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	Chipped and peeling paint, all sides \$ 15,000.00
Foundation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Electrical	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Exterior: Estimated Cost:* \$ **23,850.00**

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Interior Condition Report

Unit: Entire unit (single family)
 Upper unit of duplex

Lower unit of duplex
 Other **Lower**

Mechanical Required Work

Heating

See Essential Repairs

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Tune boiler/furn. insp ht exchanger	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Electrical

See Essential Repairs

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Plumbing

See Essential Repairs

Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace kitchen sink faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Windows

Replace broken glass n/a Yes \$

Repair or replace sash n/a Yes \$

Doors

Repair or replace doors n/a Yes **Bedroom, Bathroom** \$ **1,000.00**

Repair or repl. locks/latches n/a Yes *Self Help* \$

Walls/Ceilings

See Essential Repairs

Repair or repl. @ defective n/a Yes \$

Fire Safety

See Essential Repairs

Install smoke/CO alarm:bsmt. n/a Yes *Self Help* \$

Install smoke/CO alarm: 1st flr. n/a Yes *Self Help* \$

Install smoke/CO alarm: 2nd flr. n/a Yes *Self Help* \$

Handrails

Repair/replace defective n/a Yes *Self Help* \$

Stairs

Repair defective n/a Yes \$

Floors

Repair defective n/a Yes **Buckled hardwood floor dining room** \$ **750.00**

Other

n/a Yes \$

n/a Yes \$

n/a Yes \$

n/a Yes \$

Interior: Estimated Cost: \$ 1,750.00

Interior Condition Report

Unit: Entire unit (single family)
 Upper unit of duplex

See Essential Repairs
 Lower unit of duplex
 Other 2nd floor unit

Mechanical Required Work

Heating

See Essential Repairs

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Tune boiler/furn. insp ht exchanger	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Electrical

See Essential Repairs

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Plumbing

Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 600.00
Repair/replace kitchen sink faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Windows

Replace broken glass n/a Yes \$

Repair or replace sash n/a Yes \$

Doors

Repair or replace doors n/a Yes **Bathroom** \$ **500.00**

Repair or repl. locks/latches n/a Yes *Self Help* \$

Walls/Ceilings

See Essential Repairs

Repair or repl. @ defective n/a Yes \$

Fire Safety

See Essential Repairs

Install smoke/CO alarm:bsmt. n/a Yes *Self Help* \$

Install smoke/CO alarm: 1st flr. n/a Yes *Self Help* \$

Install smoke/CO alarm: 2nd flr. n/a Yes *Self Help* \$

Handrails

Repair/replace defective n/a Yes *Self Help* \$

Stairs

Repair defective n/a Yes \$

Floors

Repair defective n/a Yes \$

Other

n/a Yes \$

n/a Yes \$

n/a Yes \$

n/a Yes \$

Interior: Estimated Cost: \$ 1,100.00

Interior Condition Report

Unit: Entire unit (single family) Lower unit of duplex
 Upper unit of duplex Other **Third floor unit**

Mechanical Required Work

Heating

See Essential Repairs

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Tune boiler/furn. insp ht exchanger	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Electrical

See Essential Repairs

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Plumbing

Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace kitchen sink faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 350.00
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Windows

Replace broken glass n/a Yes \$

Repair or replace sash n/a Yes \$

Doors

Repair or replace doors n/a Yes \$

Repair or repl. locks/latches n/a Yes Self Help \$

Walls/Ceilings

See Essential Repairs

Repair or repl. @ defective n/a Yes \$

Fire Safety

See Essential Repairs

Install smoke/CO alarm:bsmt. n/a Yes Self Help \$

Install smoke/CO alarm: 1st flr. n/a Yes Self Help \$

Install smoke/CO alarm: 2nd flr. n/a Yes Self Help \$

Handrails

Repair/replace defective n/a Yes Self Help \$

Stairs

Repair defective n/a Yes \$

Floors

Repair defective n/a Yes \$

Other

n/a Yes \$

n/a Yes \$

n/a Yes \$

n/a Yes \$

Interior: Estimated Cost: \$ 350.00

Total Exterior and Interior Cost:* \$ 94,600.00

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Inspected Candace Eubanks

9/10/2025

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start.

Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants *may* be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants *may* be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located at 841 N. Broadway, 1st Floor.