

Scope of Work for Property Located at: 1254 N 24th St

Property is: Single Family Duplex Other **3 Unit**

Date: 2/6/2017

Below is the minimum requirement to meet health and safety issues. The City of Milwaukee, the Redevelopment Authority, and their representatives take no responsibility for problems discovered after the inspection date, or for omissions through error or oversight. The list does not necessarily include work required by private lenders, insurance companies, or by the Federal Block Grant or HOME programs.

Exterior Condition Report

Location Site	Required Work		Note/Comments	Cost
	Landscaping	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	<i>Self Help</i>	\$ 200.00
	Steps/Handrails	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>		\$ 125.00
	Service walks	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Fencing	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	Along old garage foundation walls	\$ 1,000.00
	Parking	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Retaining walls	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
Garage	Singles: repair	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Shingles: Roof over existing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Shingles:Tear off & re-roof	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Gutters/downspouts	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Flashing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Eaves	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Siding	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Doors	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Windows	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Slab	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Paint	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Electrical	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
Porches	Roof	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Deck-upper	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Deck--lower	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Steps/handrails	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	Provide risers on East jump porch steps	\$ 150.00
	Ceiling	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Guardrails	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Structural	n/a <input type="checkbox"/> Yes <input type="checkbox"/>		\$
	Paint	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	Paint or stain East jump porch	\$ 300.00
	Other	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	Repair cracked/deteriorated jump porch boards	\$ 200.00
House	Chimney	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>	Tuckpoint chimneys and repair missing flue pipe	\$ 1,000.00
	Shingles: repair	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/>		\$ 400.00

Shingles: Roof over existing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Shingles:Tear off & re-roof	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Gutters/downspouts	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Flashing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Eaves	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Siding	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	Siding and trim repairs 200.00
Storm Doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Prime ("main") Doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	500.00
Storm Windows	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Prime ("main") Windows	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	Including storms & screens 2,000.00
Paint	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
Foundation	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	Tuckpoint interior & exterior assorted areas 500.00
Electrical	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,500.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	Address labels on back of dwelling 50.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
					Exterior: Estimated Cost:*	\$ 9,725.00

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Interior Condition Report

Unit: Entire unit (single family) Lower unit of duplex
 Upper unit of duplex Lower unit

Mechanical Required Work

Heating

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Tune boiler/furn. insp ht exchange	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	Including re-connecting exhaust pipes 350.00

Electrical

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	200.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,000.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Plumbing	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	400.00
	Repair/replace kitchen sink fauce	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
	Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	750.00
	Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
	Repair water piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	900.00
	Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
	Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,300.00
	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Windows	Replace broken glass	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair or replace sash	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Doors	Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	240.00
Walls/Ceilings	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,100.00
Paint	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	60.00
	Install smoke/CO alarm:bsmt.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	120.00
Fire Safety	Install smoke/CO alarm: 1st flr.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	
	Install smoke/CO alarm: 2nd flr.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Handrails	Repair/replace defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	250.00
	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Floors	Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,200.00
		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	200.00
Other		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Interior Condition Report

Unit: Entire unit (single family) Lower unit of duplex
 Upper unit of duplex Upper North Unit

Mechanical Required Work

Heating

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
-----------------------	-----	--------------------------	-----	--------------------------	----	--

Electrical

Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	3,100.00
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Tune boiler/furn. insp ht exchange	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,000.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Plumbing

Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	400.00
Repair/replace kitchen sink fauce	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	900.00
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,300.00

Complete bath

Windows	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Replace broken glass	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Doors	Repair or replace sash	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Walls/Ceilings	Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	60.00
	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Paint	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,800.00
	Install smoke/CO alarm:bsmt.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Fire Safety	Install smoke/CO alarm: 1st flr.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Install smoke/CO alarm: 2nd flr.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	90.00
	Repair/replace defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Handrails	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Stairs	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	150.00
Floors	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Other		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	150.00
		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Interior Condition Report

Unit: Entire unit (single family) Lower unit of duplex
 Upper unit of duplex Upper South Unit

Mechanical Required Work

Heating

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	3,100.00
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Tune boiler/furn. insp ht exchange	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Electrical

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

	Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Upgrade service	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,000.00
	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Plumbing	Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	400.00
	Repair/replace kitchen sink fauce	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
	Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	600.00
	Repair water piping	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	900.00
	Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,300.00
	Other	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,300.00
	Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Windows	Replace broken glass	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair or replace sash	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Doors	Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	120.00
Walls/Ceilings	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00
Paint	Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	1,500.00
Fire Safety	Install smoke/CO alarm:bsmt.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Install smoke/CO alarm: 1st flr.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
	Install smoke/CO alarm: 2nd flr.	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	60.00
Handrails	Repair/replace defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Stairs	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Floors	Repair defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	150.00
		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	100.00
		n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	
		n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Interior: Estimated Cost:						\$	44,200.00

Total Exterior and Interior Cost:* \$ **53,925.00**

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Inspected by: Mark Stack

Date: 2/3/2017

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start. Permits are also required for other work such as new siding, new drywall, new doors. Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants *may* be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants *may* be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located at 7630 W. Mill Road.