

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	C	A	D	A	A	P	P	Sorted by:
ia	o	Acc	De	Air	A	FD	ri	Area/Mat/Zone
bl	nd	esses	bris	flow	HERA		or	Disposition All
e	iti			#			ity	Selected:
	on							

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition						Response	Quantity	
101	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	CPTM	CARPET MASTIC	CPTM	Non-ACM							0 sf	
	ZR	CPTMR	CARPETING, Replacement & Associated Mastic NOTE: Residual mastic from old carpeting.	CPTMR	Non-Suspect							0 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM							0 sf	
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI3	Non-Suspect							0 sf	
	Z1	DIFFR	DUCT INSULATION, Fiberglass w/ Foil Jacket & Resinous Seams NOTE: Above ceiling.	DI4	ACM	N	ND	N	N	N	LPD 14	O&M	50 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	LPD 14	O&M	1 sf
	Z1	MSNV	MASONITE PANELS, w/ Vinyl-facing NOTE: Demountable partitions.	MSNT1	Non-Suspect								0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM								12 ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect								0 lf
	Z1	WBM	WALL BASE MASTIC NOTE: Residual mastic from old w all base.	WBM	Non-ACM								0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic NOTE: Black.	WBR4	Non-Suspect								0 sf
	Z1	WCV	WALL COVERING, Vinyl	VWC	Non-ACM								0 sf
	101 PASS	Z1	CPTM	CARPET MASTIC NOTE: Residual mastic from old carpeting.	CPTM	Non-ACM							0 sf
ZR		CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect							0 sf	
Z1		CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM							0 sf	
Z1		DIFFR	DUCT INSULATION, Fiberglass w/ Foil Jacket & Resinous Seams NOTE: Above ceiling.	DI4	ACM	N	ND	N	N	N	LPD 14	O&M	70 sf
Z1		MSNV	MASONITE PANELS, w/ Vinyl-facing NOTE: Demountable partitions.	MSNT1	Non-Suspect							0 sf	
Z1		PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM								25 ea
Z1		PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect								0 lf
ZR		WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic NOTE: Black.	WBR4	Non-Suspect								0 sf
Z1	WCV	WALL COVERING, Vinyl	VWC	Non-ACM								0 sf	
101-1	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	CPTM	CARPET MASTIC NOTE: Residual mastic from old carpeting.	CPTM	Non-ACM							0 sf	
	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect							0 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM							0 sf	

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	F	C	A	D	A	A	P	P	Sorted by: Area/Matl/Zone	Disposition All	Selected:
						r	o	c	e	i	r	r	r			
						i	n	c	b	r	e	i	i			
						a	d	e	r	f	a	f	p			
						b	e	s	s	l	e	d	r			
						l	e			o	#		i			
						e				w			t			
													y			
														Response	Quantity	
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI3	Non-Suspect											0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N		LPD 14		O&M	1 sf	
	Z1	MSNV	MASONITE PANELS, w / Vinyl-facing NOTE: Demountable partitions.	MSNT1	Non-Suspect											0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM											4 ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect											0 lf
	Z1	WBM	WALL BASE MASTIC NOTE: Residual mastic from old w all base.	WBM	Non-ACM											0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic NOTE: Black.	WBR4	Non-Suspect											0 sf
	Z1	WCV	WALL COVERING, Vinyl	VWC	Non-ACM											0 sf
101-4	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt											0 sf
	Z1	CPT*	CARPETING *	CPT	Non-Suspect											0 sf
	Z1	CPTM	CARPET MASTIC	CPTM	Non-ACM											0 sf
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM											0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI3	Non-Suspect											0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N		LPD 14		O&M	1 sf	
	Z1	MSNV	MASONITE PANELS, w / Vinyl-facing NOTE: Demountable partitions.	MSNT1	Non-Suspect											0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM											4 ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect											0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM											0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM											0 sf
	Z1	WCV	WALL COVERING, Vinyl	VWC	Non-ACM											0 sf
101-5	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt											0 sf
	Z1	CKG	CAULKING/SEALANT NOTE: Brown caulking applied around window s & window panel inserts (transite).	CKG2	ACM	N	ND	N	N	N		LPD 14		O&M	1 sf	
	Z1	CPTM	CARPET MASTIC NOTE: Residual mastic from old carpeting.	CPTM	Non-ACM											0 sf
	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect											0 sf
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM											0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI3	Non-Suspect											0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N		LPD 14		O&M	1 sf	
	Z1	MSNV	MASONITE PANELS, w / Vinyl-facing NOTE: Demountable partitions.	MSNT1	Non-Suspect											0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	Co	Ac	De	Ai	AH	PF	Pr	Sorted by:
ia	nd	ces	ber	ir	ER	D	io	Area/Matl/Zone
bl	iti	s	ris	fl	A		ri	Disposition All
e	on		s	w	#		ty	Selected:

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition					Response	Quantity		
103	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt						0 sf		
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM						12 sf		
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM						0 sf		
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM						0 sf		
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt						0 sf		
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM						4 ea		
				└ NOTE: Above ceiling.									
Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf		
			└ NOTE: Above ceiling.										
104	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt						0 sf		
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM						0 sf		
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	D3	Non-Suspect						0 sf		
	Z1	DJMR	DUCT JOINT SEALANT, Red	DJMR	ACM	N	ND	N	N	N	LPD 14	O&M	2 sf
				└ NOTE: Above ceiling.									
	ZR	FSPC	FIRE STOP PACKING, Cementitious	FSPC	Non-Suspect							0 sf	
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect							0 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M	225 sf
				└ NOTE: Tan & w hite 'mottled' accenting.									
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M	225 sf
Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM							15 ea		
			└ NOTE: Above ceiling.										
Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf		
			└ NOTE: Above ceiling.										
Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM							0 sf		
Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM							0 sf		
104-1	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt						0 sf		
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM						8 sf		
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM						0 sf		
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM						0 sf		
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt						0 sf		
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM						0 ea		
	Z1	PIAX	PIPE INSULATION, Armaflex	PIAX	Non-Suspect						0 lf		
				└ NOTE: No hard fittings in this area.									
Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf		
104-2	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt						0 sf		
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM						0 sf		
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl *	FT1	ACM	N	ND	Y	N	N	SPD 12	O&M	12 sf
				└ NOTE: Tan & w hite 'mottled' accenting.									
Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	LPD 14	O&M	12 sf	

* Must check the Disposition of the mastic associated w ith this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	F	C	A	D	A	A	P	P	Sorted by: Area/Matl/Zone	Disposition All	Selected:
						r	o	c	e	i	H	F	r			
						i	n	c	r	r	E	D	i			
						a	d	e	i	f	R	P	p			
						b	e	s	s	l	A	D	r			
						l	e			o	#		i			
						e				w			t			
													y			
														Response	Quantity	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Inside w all behind access panel.	PFIF	Non-ACM										2ea	
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Inside w all behind access panel.	PIF	Non-Suspect										0 lf	
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf	
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf	
105	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										15 sf	
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf	
106	Z1	AHUIFC	AIR HANDLING UNIT INSULATION, Fiberglass w / Canvas Jacket	FHI	Non-ACM										813 sf	
	Z1	DC	DUCT CONNECTORS, Canvas Vibration Isolators	DC	Non-ACM										7ea	
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket	DI1	Non-ACM										0 sf	
	Z1	HWTIF	HOT WATER TANK INSULATION, Fiberglass	HWT	Non-Suspect										0 sf	
	Z1	PFIAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines	PFIAQ	Non-ACM										36ea	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: VERIFY MATERIALS IN THIS ROOM, 916 REPORTED MATERIAL THAT COULD BE WOOLFELT 10-21-13 !!!!!!!!!!!!!	PFIF	Non-ACM										26ea	
	Z1	PIAQ	PIPE INSULATION, Aquatherm	PIAQ	Non-Suspect										0 lf	
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf	
	Z1	STNS	STAIR TREADS, Non-Skid Strips	ST	Non-Suspect										210 sf	
107	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf	
	ZR	CTRP	CEILING TILE PATCH, Replacement Panels NOTE: 2'x2' mineral board panels.	CTR	Non-Suspect										0 sf	
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI3	Non-Suspect										0 sf	
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	N	N	N	LPD 14	O&M	3sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & w hite 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N	N	N	N	SPD 12	O&M	673 sf
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N	N	N	N	LPD 14	O&M	673 sf
	Z1	PFIAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines NOTE: Above ceiling.	PFIAQ	Non-ACM										9ea	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										32ea	
	Z1	PIAQ	PIPE INSULATION, Aquatherm	PIAQ	Non-Suspect										0 lf	
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf	
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf	
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf	

* Must check the Disposition of the mastic associated w ith this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	Co	Ac	De	Ai	AH	PF	Pr	Sorted by: Area/Matl/Zone Disposition All Selected:	
ia	nd	ce	er	ri	ER	D	io	Response	Quantity
bl	it	ss	is	fl	A		ri		
e	io	s	s	w	#		ty		

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Fr	Co	Ac	De	Ai	AH	PF	Pr	Response	Quantity	
108	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CPT*	CARPETING * └ NOTE: On walls.	CPT	Non-Suspect										0 sf	
	Z1	CPTM	CARPET MASTIC └ NOTE: On walls.	CPTM	Non-ACM										0 sf	
	ZR	CPTMR	CARPETING, Replacement & Associated Mastic	CPTMR	Non-Suspect										0 sf	
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels *	CT5	Non-ACM										0 sf	
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf	
	Z1	CTM	CEILING TILE MASTIC	CT5M	Non-ACM										0 sf	
	Z1	DIFFR	DUCT INSULATION, Fiberglass w/ Foil Jacket & Resinous Seams └ NOTE: Above ceiling (paper jacket in some areas).	DI4	ACM	N	ND	N	N	N			LPD 14	O&M	1,500 sf	
	Z1	DJMR	DUCT JOINT SEALANT, Red └ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N			LPD 14	O&M	20 sf	
	Z1	DWJC	WALLBOARD, Dryw all/Joint Compound System └ NOTE: Above ceiling.	DW	Non-ACM**										0 sf	
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf	
	Z1	MSNP	MASONITE PANELS, Perforated	MSNT2	Non-Suspect										0 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines └ NOTE: Above ceiling.	PFIF	Non-ACM										6 ea	
	Z1	PIF	PIPE INSULATION, Fiberglass └ NOTE: Above ceiling.	PIF	Non-Suspect										0 lf	
	Z1	WB4K	WALL BASE, 4" Black Vinyl *	WB3	Non-ACM										20 sf	
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf	
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic └ NOTE: Black.	WBR4	Non-Suspect										0 sf	
	109	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
		Z1	CKBDM	CHALKBOARD/TACKBOARD MASTIC	TKBM	Assumed	N	ND	N	N	N			LPD 14	O&M	1,120 sf
		Z1	CKG	CAULKING/SEALANT └ NOTE: Brown caulking applied around windows & window panel inserts (transite).	CKG2	ACM	N	ND	N	N	N			LPD 14	O&M	2 sf
Z1		CKG	CAULKING/SEALANT └ NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf	
Z1		CPT*	CARPETING *	CPT	Non-Suspect										0 sf	
Z1		CPTM	CARPET MASTIC	CPTM	Non-ACM										0 sf	
Z1		CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										80 sf	
Z1		CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf	
Z1		CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf	
ZR		CTRP	CEILING TILE PATCH, Replacement Panels	CTR	Non-Suspect										0 sf	
Z1		DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting └ NOTE: Above ceiling.	DI3	Non-Suspect										0 sf	
Z1		DIFFR	DUCT INSULATION, Fiberglass w/ Foil Jacket & Resinous Seams	DI4	ACM	N	ND	N	N	N			LPD 14	O&M	800 sf	
Z1		DJMR	DUCT JOINT SEALANT, Red └ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N			LPD 14	O&M	40 sf	
Z1		DWJC	WALLBOARD, Dryw all/Joint Compound System └ NOTE: Above ceiling.	DW	Non-ACM**										0 sf	
Z1		FSM	SHEET FLOORING MASTIC	FSM	Non-ACM										1,000 sf	

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	Co	Ac	De	Ai	AH	PF	Pr	Sorted by: Area/Matl/Zone Disposition All Selected:	
ia	nd	ce	br	rf	ER	D	io	Response	Quantity
bl	iti	ss	is	fl	A		ri		
e	on			w	#		ty		

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Fr	Co	Ac	De	Ai	AH	PF	Pr	Response	Quantity
117	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKG	CAULKING/SEALANT └ NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf
	Z1	CPT*	CARPETING *	CPT	Non-Suspect										0 sf
	Z1	CPTM	CARPET MASTIC	CPTM	Non-ACM										0 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting └ NOTE: Above ceiling.	DI3	Non-Suspect										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red └ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	N	N	LPD 14	O&M	2 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
118	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										15 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red └ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	N	LPD 14	O&M	1 sf	
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
Z1	FTRS2	FLOOR TILE REDUCING STRIPS, Black Vinyl *	FTRS2	Non-ACM										0 sf	
119	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										5 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
120	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKG	CAULKING/SEALANT └ NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf
	Z1	CPTM	CARPET MASTIC └ NOTE: Residual mastic from old carpeting.	CPTM	Non-ACM										0 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket └ NOTE: Above ceiling.	DI1	Non-ACM										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red └ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	N	LPD 14	O&M	2 sf	
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
122	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKBDM	CHALKBOARD/TACKBOARD MASTIC	TKBM	Assumed	N	ND	N	N	N	N	LPD 14	O&M	1,120 sf	
	Z1	CKG	CAULKING/SEALANT └ NOTE: Brown caulking applied around window s & window panel inserts (transite).	CKG2	ACM	N	ND	N	N	N	N	LPD 14	O&M	2 sf	

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	F	C	A	D	A	A	P	P	Sorted by: Area/Matl/Zone	Disposition All	Selected:
						r	o	c	e	a	H	F	r			
						i	n	c	b	i	E	D	i			
						a	d	e	r	r	R	P	p			
						b	i	s	f	f	A	D	r			
						l	t		l	l	#		i			
						e	i		o				t			
							o						y			
							n							Response	Quantity	
123A	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf	
	Z1	DIFF	DUCT INSULATION, Fiberglass w / Foil Jacket NOTE: Above ceiling.	D13	Non-Suspect										0 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & w hite 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N			SPD 12	O&M	88 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N			LPD 14	O&M	88 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										5ea	
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf	
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf	
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf	
125	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf	
	Z1	CPM	CEILING PANEL MASTIC NOTE: Associated w ith tectum panels.	CT2M	Assumed	N	ND	N	N	N			LPD 14	O&M	220 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf	
	ZR	CTRP	CEILING TILE PATCH, Replacement Panels NOTE: 2'x2' mineral board panel.	CTR	Non-Suspect										0 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & w hite 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N			SPD 12	O&M	665 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N			LPD 14	O&M	665 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										2ea	
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf	
	Z1	RD/FP	ROOM DIVIDER, Folding Rigid Panel Partition	RD/FP	Non-ACM										0 sf	
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf	
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf	
	Z1	WPTC	WALL PANELS, Woven Cellulose [Tectum] Sheeting	CT2	Non-ACM										0 sf	
125A	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf	
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf	
	Z1	DIFF	DUCT INSULATION, Fiberglass w / Foil Jacket NOTE: Above ceiling.	D13	Non-Suspect										0 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & w hite 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N			SPD 12	O&M	56 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N			LPD 14	O&M	56 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										2ea	
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf	
	Z1	WB4B	WALL BASE, 4" Brow n Vinyl *	WB1	Non-ACM										0 sf	

* Must check the Disposition of the mastic associated w ith this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	Co	Ac	De	Ai	AH	PF	Pr	Sorted by: Area/Matl/Zone Disposition All Selected:	
ia	nd	ce	br	rf	ER	D	io	Response	Quantity
ble	iti	ss	ris	flow	A		ri		
e	on			#			ty		

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Fr	Co	Ac	De	Ai	AH	PF	Pr	Response	Quantity
						ia	nd	ce	br	rf	ER	D	io		
						ble	iti	ss	ris	flow	A		ri		
						e	on			#			ty		
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
	Z1	WCV	WALL COVERING, Vinyl	VWC	Non-ACM										0 sf
127A	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf
	Z1	FT12WT	FLOOR TILE, 12"x12" White Vinyl * NOTE: Gray & light blue 'mottled' accenting.	FT2	ACM	N	ND	Y	N	N		SPD 12		O&M	450 sf
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N		LPD 14		O&M	450 sf
	Z1	PFAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines	PFAQ	Non-ACM										8ea
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM										18ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
128	Z1	CPM	CEILING PANEL MASTIC NOTE: Associated with tectum panels (presence not verified).	CT2M	Assumed	N	ND	N	N	N		LPD 14		O&M	420 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										170 sf
	Z1	CT11M*	CEILING TILE, 12"x12" Mineral Board Panels *	CT5	Non-ACM										0 sf
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	CTM	CEILING TILE MASTIC	CT5M	Non-ACM										2,320 sf
	Z1	DIFFR	DUCT INSULATION, Fiberglass w/ Foil Jacket & Resinous Seams NOTE: Above ceiling.	DI4	ACM	N	ND	N	N	N		LPD 14		O&M	700 sf
	Z1	DWJC	WALLBOARD, Drywall/Joint Compound System NOTE: Above ceiling.	DW	Non-ACM**										0 sf
	Z1	EWI	ELECTRICAL WIRE INSULATION, Woven Cloth NOTE: On light fixtures.	EWI	Non-ACM										6 lf
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & white 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N		SPD 12		O&M	2,320 sf
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N		LPD 14		O&M	2,320 sf
	Z1	PFAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines NOTE: Above ceiling.	PFAQ	Non-ACM										8ea
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										36ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
	Z1	RD/FP	ROOM DIVIDER, Folding Rigid Panel Partition	RD/FP	Non-ACM										0 sf
	Z1	TKBDV	TACKBOARDS/TACKSTRIPS, Vinyl Covered	TKBD	Non-ACM										0 sf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
	Z1	WPTC	WALL PANELS, Woven Cellulose [Tectum] Sheeting	CT2	Non-ACM										0 sf
129	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CT22M	CEILING TILE, 2'x2' Mineral Board Panels	CT4	Non-ACM										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:	Response	Quantity
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines ↳ NOTE: Above ceiling.	PFIF	Non-ACM											8ea
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: Above ceiling.	PIF	Non-Suspect											0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM											0 sf
	Z1	WB6B	WALL BASE, 6" Brown Vinyl *	WB2	Non-ACM											0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM											0 sf
130B	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM											180 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM											0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt											0 sf
130C	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt											0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM											8 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM											0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM											0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt											0 sf
	Z1	PFIAX	PIPE FITTING INSULATION, Mudded Joints on Armaflex Lines	PFIAX	Non-ACM											0ea
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines ↳ NOTE: Above ceiling.	PFIF	Non-ACM											3ea
	Z1	PIAX	PIPE INSULATION, Armaflex	PIAX	Non-Suspect											0 lf
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: Above ceiling.	PIF	Non-Suspect											0 lf
131	Z1	BBICS	BOILER STACK/BREECHING INSULATION, Calcium Silicate w / Canvas Jacket	BBI	Non-ACM											0 sf
	Z1	BBIRS	BOILER STACK/BREECHING INSULATION, Refractory w / Steel Jacket	BBIRS	Assumed	N	ND	N	N	N	N	LPD 14		O&M	100 sf	
	Z1	BDR	BOILER DOOR REFRACTORY, Cast	BR	ACM	N	ND	N	N	N	N	LPD 14		O&M	6 sf	
	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt											0 sf
	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt											0 sf
	Z1	CHI	CHILLER INSULATION ↳ NOTE: Armaflex composition.	CHI	Non-Suspect											0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket	DI1	Non-ACM											0 sf
	ZR	DWJC	WALLBOARD, Dryw all/ Joint Compound System	DWJC	Non-Suspect											0 sf
	Z1	EGXIC	EMERGENCY GENERATOR EXHAUST INSULATION, Calcium Silicate w / Canvas Cover	EGEPI	ACM	N	ND	Y	N	N	N	SPD 12		O&M	7 sf	
	Z1	FDMF	FIRE DOORS, Metal Shell w / Fiberglass Core	FD	Non-Suspect											2ea
	ZR	FSPC	FIRE STOP PACKING, Cementitious	FSPC	Non-Suspect											0 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect											0 sf
	Z1	FTRSBN	FLOOR TILE REDUCING STRIPS, Brown Vinyl *	FTRS1	ACM	N	ND	Y	N	N	N	SPD 12		O&M	1 sf	
	Z1	HWTIF	HOT WATER TANK INSULATION, Fiberglass	HWT	Non-Suspect											0 sf
	Z1	PFIAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines	PFIAQ	Non-ACM											40ea
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM											140ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect											0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect											0 lf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect											0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	C	A	D	A	A	P	P	Sorted by: Area/Mat/Zone	
ia	o	cc	eb	ir	HE	FD	ri	Disposition All	
bl	nd	es	ris	r	RA		or	Selected:	
e	it	s	s	l	#		ity		
	ion			ow					

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition						Response	Quantity	
	ZR	WMIR	WATER METER INSULATION, Replacement	WMIR	Non-Suspect							0 lf	
	Z1	XTIM	EXPANSION TANK INSULATION, Magnesia	ETI	ACM	N	ND	Y	N	N	SPD 12	O&M	6 sf
131A	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt							0 sf	
	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect							0 sf	
	Z1	PFIAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines	PFIAQ	Non-ACM							0ea	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM							0ea	
	Z1	PIAQ	PIPE INSULATION, Aquatherm	PIAQ	Non-Suspect							0 lf	
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf	
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect							0 lf	
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect							0 sf	
131B	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	NSM	NO SUSPECT MATERIALS	NSM	Non-Suspect							0 sf	
131C	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	NSM	NO SUSPECT MATERIALS	NSM	Non-Suspect							0 sf	
131D	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt							0 sf	
	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	ZR	DWJC	WALLBOARD, Dryw all/Joint Compound System	DWJC	Non-Suspect							0 sf	
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect							0 sf	
	Z1	PFIAQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines	PFIAQ	Non-ACM							0ea	
	Z1	PIAQ	PIPE INSULATION, Aquatherm	PIAQ	Non-Suspect							0 lf	
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: No hard fittings in this area.	PIF	Non-Suspect							0 lf	
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect							0 lf	
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic	WBR4	Non-Suspect							0 sf	
132	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket	DI1	Non-ACM							0 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM							7ea	
	Z1	PIAQ	PIPE INSULATION, Aquatherm ↳ NOTE: No hard fittings in this area.	PIAQ	Non-Suspect							0 lf	
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf	
133	Z1	C	CONCRETE, Floors/Walls/Ceilings	C	Exempt							0 sf	
	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt							0 sf	
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket	DI1	Non-ACM							0 sf	
	Z1	FTRSBN	FLOOR TILE REDUCING STRIPS, Brown Vinyl *	FTRS1	ACM	N	ND	Y	N	N	SPD 12	O&M	1 sf
	Z1	MSNP	MA SONITE PANELS, Perforated ↳ NOTE: Toolboard panels.	MSNT2	Non-Suspect							0 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM							16ea	
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect							0 lf	

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:
-----------------------------	---	----------------------------	----------------------------	---------------------------------	----------------------------	-------------	--------------------------------------	---

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Response	Quantity
134	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM		12 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM		0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w/ Canvas Jacket	DI1	Non-ACM		0 sf
134A	Z1	AHUIFC	AIR HANDLING UNIT INSULATION, Fiberglass w/ Canvas Jacket	FHI	Non-ACM		813 sf
	Z1	DC	DUCT CONNECTORS, Canvas Vibration Isolators	DC	Non-ACM		8 ea
	ZR	DCV	DUCT CONNECTORS, Vinyl Vibration Isolators	DCV	Non-Suspect		0 ea
	Z1	DIFC	DUCT INSULATION, Fiberglass w/ Canvas Jacket	DI1	Non-ACM		0 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect		0 sf
	Z1	GKD	GASKETS, Duct ↳ NOTE: @ coil assembly.	DG	Non-ACM		2 ea
	Z1	PFAIQ	PIPE FITTING INSULATION, Mudded Joints on Aquatherm Lines ↳ NOTE: Above ceiling.	PFAIQ	Non-ACM		60 ea
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM		125 ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect		0 lf
Z1	STNS	STAIR TREADS, Non-Skid Strips	ST	Non-Suspect		210 sf	
135	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM		8 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w/ Mineral Board Backing	CT1	Non-ACM		0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM		0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt		0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines ↳ NOTE: Above ceiling.	PFIF	Non-ACM		2 ea
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: Above ceiling.	PIF	Non-Suspect		0 lf
136	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM		10 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w/ Mineral Board Backing	CT1	Non-ACM		0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM		0 sf
	ZR	CTRP	CEILING TILE PATCH, Replacement Panels ↳ NOTE: 12"x12" mineral board panel.	CTR	Non-Suspect		0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt		0 sf
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: Above ceiling. No associated fittings are in this area.	PIF	Non-Suspect		0 lf
137	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w/ Mineral Board Backing	CT1	Non-ACM		0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w/ Canvas Jacket ↳ NOTE: Above ceiling.	DI1	Non-ACM		0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	C	A	D	A	A	P	P	Sorted by: Area/Matl/Zone	
ia	o	cc	eb	ir	H	ri	ri	Disposition	All
bl	nd	es	ris	r	E	or	or	Selected:	
e	it	s	s	fl	R	it	it		
	ion			w	A	y	y		
				#	P				
					D				

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Fr	C	A	D	A	A	P	P	Response	Quantity
						ia	o	cc	eb	ir	H	ri	or		
						bl	nd	es	ris	r	E	or	it		
						e	it	s	s	fl	A	y	y		
										#	P				
											D				
	Z1	DITP	DUCT INSULATION, Troweled-on Plaster NOTE: Above ceiling.	DI2	Non-ACM										30 sf
	Z1	NSFS	NON-SKID FLOOR STRIPS	NS	Non-Suspect										0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										8 ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
	Z1	QFTM	QUARRY FLOOR TILE & MORTAR	QT	Exempt										0 sf
138	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket NOTE: Above ceiling.	DI1	Non-ACM										0 sf
	Z1	DIFFR	DUCT INSULATION, Fiberglass w / Foil Jacket & Resinous Seams NOTE: Above ceiling.	DI4	ACM	N	ND	Y	N	N		SPD 12	O&M	180 sf	
	Z1	NSFS	NON-SKID FLOOR STRIPS	NS	Non-Suspect										0 sf
	Z1	OVC	CONVECTION OVEN, All Components [liners, doors, gaskets, etc.] NOTE: 'South Bend' brand ovens. No components tested.	OVC	Assumed	N	ND	Y	N	N		SPD 12	O&M	1ea	
	Z1	OVD	DECK OVEN, All Components [liners, doors, gaskets, etc.] NOTE: No brand tag on ovens. No components tested.	OR	Assumed	N	ND	Y	N	N		SPD 12	O&M	2ea	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										1 ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
	Z1	QFTM	QUARRY FLOOR TILE & MORTAR	QT	Exempt										0 sf
139	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	DIFFR	DUCT INSULATION, Fiberglass w / Foil Jacket & Resinous Seams NOTE: Above ceiling.	DI4	ACM	N	ND	N	N	N		LPD 14	O&M	180 sf	
	Z1	FT12CM	FLOOR TILE, 12"x12" Cream Vinyl * NOTE: Tan & white 'mottled' accenting.	FT1	ACM	N	ND	Y	N	N		SPD 12	O&M	288 sf	
	Z1	FTM	FLOOR TILE MASTIC	FTM	ACM	N	ND	N	N	N		LPD 14	O&M	288 sf	
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM										9ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
140	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKBDM	CHALKBOARD/TACKBOARD MASTIC	TKBM	Assumed	N	ND	N	N	N		LPD 14	O&M	1,120 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Brown caulking applied around window s & window panel inserts (transite).	CKG2	ACM	N	ND	N	N	N		LPD 14	O&M	1 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										1 sf
	Z1	CPT*	CARPETING *	CPT	Non-Suspect										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Sorted by: Area/Matl/Zone Disposition All Selected:
-----------------------------	---	----------------------------	----------------------------	---------------------------------	----------------------------	-------------	--------------------------------------	---

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Response	Quantity
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM		10ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect		0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM		0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM		0 sf
141	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	CKG	CAULKING/SEALANT NOTE: Brown caulking applied around windows & window panel inserts (transite).	CKG2	ACM	N ND N N N LPD 14	O&M 1 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM		0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting NOTE: Above ceiling.	DI3	Non-Suspect		0 sf
	Z1	DWJC	WALLBOARD, Drywall/Joint Compound System NOTE: Above ceiling.	DW	Non-ACM**		0 sf
	ZR	DWJC	WALLBOARD, Drywall/Joint Compound System	DWJC	Non-Suspect		0 sf
	Z1	FSM	SHEET FLOORING MASTIC	FSM	Non-ACM		1,020 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect		0 sf
	Z1	FSVWT	SHEET FLOORING, White Vinyl * NOTE: Green accenting.	FS	Non-ACM		0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines NOTE: Above ceiling.	PFIF	Non-ACM		30ea
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling.	PIF	Non-Suspect		0 lf
	Z1	RDFP	ROOM DIVIDER, Folding Rigid Panel Partition	RD/FP	Non-ACM		0 sf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM		0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM		0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic NOTE: Black.	WBR4	Non-Suspect		0 sf
	Z1	WSCS	WINDOW SILLS, Cut/Polished Stone	MBL	Exempt		6 sf
	Z1	WTPTRI	WINDOW PANELS, Cementitious [Transite] w/ Insulated Core NOTE: Above ceiling & windows.	TRNS/IW P	ACM	N ND N N Y PD 13	O&M 20 sf
141A	ZR	CTGR	CERAMIC WALL TILE, Replacement Tile, Grout & Associated Mastic	CTGR	Non-Suspect		0 sf
	ZR	CTR	CEILING TILE, Replacement Panels NOTE: 2'x4' gypsum board panels.	CTR	Non-Suspect		0 sf
	ZR	DIR	DUCT INSULATION, Replacement NOTE: Fiberglass w/ foil jacket & resinous seams & flex-duct.	DIR	Non-Suspect		0 sf
	ZR	DWJC	WALLBOARD, Drywall/Joint Compound System	DWJC	Non-Suspect		0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM		0ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect		0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w/ Zeston [PVC] Fittings	PIFZ	Non-Suspect		0 lf
142	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt		0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI3	Non-Suspect		0 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect		0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Sorted by: Area/Matl/Zone
Disposition All
Selected:

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	F r i a b l e	C o n d i t i o n	A c c e s s	D e b r i s	A i r f l o w	A H E R A #	P F D	P r i o r i t y	Response	Quantity
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM										4 ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	Z1	WBM	WALL BASE MASTIC ↳ NOTE: Residual mastic from old w all base.	WBM	Non-ACM										0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic ↳ NOTE: Black.	WBR4	Non-Suspect										0 sf
143	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										530 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	PIAX	PIPE INSULATION, Armaflex ↳ NOTE: No hard fittings in this area.	PIAX	Non-Suspect										0 lf
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: No hard fittings in this area.	PIF	Non-Suspect										0 lf
143PC	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	HWTIF	HOT WATER TANK INSULATION, Fiberglass	HWT	Non-Suspect										0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM										80 ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	ZR	PIFZ	PIPE INSULATION, Fiberglass w / Zeston [PVC] Fittings	PIFZ	Non-Suspect										0 lf
144	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										410 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red ↳ NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N		LPD 14	O&M		2 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines ↳ NOTE: Above ceiling.	PFIF	Non-ACM										3 ea
	Z1	PIF	PIPE INSULATION, Fiberglass ↳ NOTE: Above ceiling.	PIF	Non-Suspect										0 lf
145	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	DIFDF	DUCT INSULATION, Flexible Fiberglass Ducting	DI3	Non-Suspect										0 sf
	ZR	FTR	FLOOR TILE, Replacement 12"x12" & Associated Mastic	FTR	Non-Suspect										0 sf
	Z1	PFIF	PIPE FITTING INSULATION, Mudded Joints on Fiberglass Lines	PFIF	Non-ACM										9 ea
	Z1	PIF	PIPE INSULATION, Fiberglass	PIF	Non-Suspect										0 lf
	Z1	WBM	WALL BASE MASTIC ↳ NOTE: Residual mastic from old w all base.	WBM	Non-ACM										0 sf
	ZR	WBR4	WALL BASE, 4" Replacement Vinyl & Associated Mastic ↳ NOTE: Black.	WBR4	Non-Suspect										0 sf
146	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

REPORT OF BUILDING MATERIALS for
FLETCHER SCHOOL

****Materials printed in BOLD must be treated as Asbestos Containing Materials****

Fr	Co	Ac	De	Ai	AH	PF	Pr	Sorted by: Area/Matl/Zone Disposition All Selected:	
ia	nd	ce	br	rf	ER	D	io	Response	Quantity
bl	it	ss	is	fl	A		ri		
e	io	s	s	w	#		ty		

Area ID	Zone	Matl Code	Material Description (notes if applicable)	S. Link	Disposition	Fr	Co	Ac	De	Ai	AH	PF	Pr	Response	Quantity
						ia	nd	ce	br	rf	ER	D	io		
						bl	it	ss	is	fl	#		ty		
	ZR	FSPC	FIRE STOP PACKING, Cementitious	FSPC	Non-Suspect										0 sf
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	PIAQ	PIPE INSULATION, Aquatherm NOTE: Above ceiling. No associated fittings are in this area.	PIAQ	Non-Suspect										0 lf
	Z1	PIF	PIPE INSULATION, Fiberglass NOTE: Above ceiling. No associated fittings are in this area.	PIF	Non-Suspect										0 lf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
148	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										15 sf
	Z1	CT11MF	CEILING TILE, 12"x12" Metal-faced w / Mineral Board Backing	CT1	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	Z1	MFT	MOSAIC FLOOR TILE & MORTAR	MT	Exempt										0 sf
149	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										8 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf
	Z1	CTG	CERAMIC WALL TILE GROUT	CR	Non-ACM										0 sf
	ZR	CTRP	CEILING TILE PATCH, Replacement Panels NOTE: 2'x2' mineral board panel.	CTR	Non-Suspect										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red	DJMR	ACM	N	ND	N	N	N	N	LPD 14	O&M	1 sf	
	Z1	FTRSBK	FLOOR TILE REDUCING STRIPS, Black Vinyl *	FTR2	Non-ACM										0 sf
150	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns & at corners.	CKG1	Non-ACM										1 sf
	Z1	CPT*	CARPETING *	CPT	Non-Suspect										0 sf
	Z1	CPTM	CARPET MASTIC	CPTM	Non-ACM										0 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf
	Z1	DIFC	DUCT INSULATION, Fiberglass w / Canvas Jacket NOTE: Above ceiling.	DI1	Non-ACM										0 sf
	Z1	DJMR	DUCT JOINT SEALANT, Red NOTE: Above ceiling.	DJMR	ACM	N	ND	N	N	N	N	LPD 14	O&M	1 sf	
	ZR	FSPR	FIRE STOP PACKING, Resinous	FSPR	Non-Suspect										0 sf
	Z1	WB4B	WALL BASE, 4" Brown Vinyl *	WB1	Non-ACM										0 sf
	Z1	WBM	WALL BASE MASTIC	WBM	Non-ACM										0 sf
151	Z1	CBM	CONCRETE BLOCK & MORTAR	CB	Exempt										0 sf
	Z1	CKBDM	CHALKBOARD/TACKBOARD MASTIC	TKBM	Assumed	N	ND	N	N	N	N	LPD 14	O&M	1,120 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Brown caulking applied around windows & window panel inserts (transite).	CKG2	ACM	N	ND	N	N	N	N	LPD 14	O&M	2 sf	
	Z1	CKG	CAULKING/SEALANT NOTE: Gray caulking applied along columns.	CKG1	Non-ACM										2 sf
	Z1	CPT*	CARPETING *	CPT	Non-Suspect										0 sf
	Z1	CPTM	CARPET MASTIC	CPTM	Non-ACM										0 sf
	Z1	CRTM	CERAMIC WALL TILE MASTIC	CRM	Non-ACM										80 sf
	Z1	CT25M	CEILING TILE, 2'x5' Mineral Board Panels	CT3	Non-ACM										0 sf

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)

Total Record Count: 958 Total Area Count: 88

Matl Types Selected: ALL

Areas Selected: ALL

* Must check the Disposition of the mastic associated with this material
** This material contains trace amounts of asbestos (<=1%)