

EXHIBIT A TO OFFER TO PURCHASE -- CITY OF MILWAUKEE SCOPE OF WORK

Scope of Work for Property Located at: 2641 South 28th Street

Property is: Single Family Duplex Other

Date: 2/13/2019 OCCUPIED VACANT

City prepared this Scope upon visual inspection only, for limited purpose. City does not warrant content or conclusions, and is not responsible for errors, omissions, or discovery of conditions that are or may constitute defects or concerns

ESSENTIAL REPAIRS. All buyers must complete Essential Repairs and obtain "Essential Repair Verification Form" and provide same to DCD within 180 days of City's deed to buyer in order to get return of performance deposit.

Location	Required Work	Note/Comments	Cost
Entire Building	Structural Violations	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing HVAC	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing Plumbing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing Electrical	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing Egress	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> guardrails at second floor - permit	\$ 400.00
	Defective/Missing Smoke Alarm	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing CO Alarm	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Defective/Missing Roof (Major)	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> assumed/snow covered	\$ 11,000.00
	Missing Window(s)	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Missing Exterior Door(s)	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
	Other	n/a <input type="checkbox"/> Yes <input checked="" type="checkbox"/> interior walls/ceilings/potential lead hazard(s)	\$ 1,000.00
Essential Repairs: Estimated Cost:*			\$ 12,400.00

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

OTHER REPAIRS (Exterior & Interior). Buyer is notified that the following are code violations that must be addressed and are subject to Department of Neighborhood Services (DNS) enforcement.

Exterior Condition Report

Location	Required Work	Note/Comments	Cost	
Site	Landscaping	n/a <input type="checkbox"/> Yes <input type="checkbox"/> Self Help	\$	
	Steps/Handrails	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Service walks	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Fencing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Parking	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Retaining walls	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
	Garage	Singles: repair	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
		Shingles: Roof over existing	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$
Shingles:Tear off & re-roof		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Gutters/downspouts		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Flashing		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Eaves		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Siding		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Doors		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Windows		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Slab		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Paint		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Electrical		n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$	
Other	n/a <input type="checkbox"/> Yes <input type="checkbox"/>	\$		

Porches

Roof	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Deck-upper	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Deck-lower	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Steps/handrails	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Ceiling	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Guardrails	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Structural	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Paint	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 700.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

House

Chimney	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles: repair	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles: Roof over existing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Shingles:Tear off & re-roof	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Gutters/downspouts	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 500.00
Flashing	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Eaves	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Siding	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Storm Doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Prime ("main") Doors	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Storm Windows	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Prime ("main") Windows	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 3,900.00 damaged/original windows
Paint	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$ 450.00
Foundation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Electrical	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$

Exterior: Estimated Cost:* **\$ 5,550.00**

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Interior Condition Report

Unit: Entire unit (single family) Lower unit of duplex
 Upper unit of duplex Other

Mechanical Required Work

Heating

Repair/replace boiler	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair radiation	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace furnace	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair ductwork	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Replace thermostat	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace grilles	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Tune furn. insp ht exchanger	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	300.00

Electrical

Repair/replace receptacles	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	50.00
Repair/replace switches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	50.00
Repair/replace fixtures	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	50.00
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Install outlets and circuits	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Upgrade service	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Plumbing

Repair/replace kitchen sink	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace kitchen sink faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace toilet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace lavatory	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	200.00
Repair/replace lavatory faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace wash tub faucet	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Unclog piping:	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair drain/waste/vent piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair water piping	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Repair/replace water heater	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	250.00
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
Other	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	

Windows

Replace broken glass	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
----------------------	-----	--------------------------	-----	--------------------------	----	--

Repair or replace sash	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
------------------------	-----	--------------------------	-----	--------------------------	----	--

Doors

Repair or replace doors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	340.00
-------------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Repair or repl. locks/latches	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	110.00
-------------------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Walls/Ceilings

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
-----------------------------	-----	--------------------------	-----	--------------------------	----	--

Paint

Repair or repl. @ defective	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	500.00
-----------------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Fire Safety

Install smoke/CO alarm:bsmt.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
------------------------------	-----	--------------------------	-----	--------------------------	----	--

Install smoke/CO alarm: 1st flr.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
----------------------------------	-----	--------------------------	-----	--------------------------	----	--

Install smoke/CO alarm: 2nd flr.	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
----------------------------------	-----	--------------------------	-----	--------------------------	----	--

Handrails

Repair/replace defective handrails	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	250.00
------------------------------------	-----	--------------------------	-----	-------------------------------------	----	---------------

Stairs

Repair defective steps	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
------------------------	-----	--------------------------	-----	--------------------------	----	--

Floors

Repair defective floors	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	2,000.00
-------------------------	-----	--------------------------	-----	-------------------------------------	----	-----------------

Other

	n/a	<input type="checkbox"/>	Yes	<input checked="" type="checkbox"/>	\$	150.00
--	-----	--------------------------	-----	-------------------------------------	----	---------------

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
--	-----	--------------------------	-----	--------------------------	----	--

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
--	-----	--------------------------	-----	--------------------------	----	--

	n/a	<input type="checkbox"/>	Yes	<input type="checkbox"/>	\$	
--	-----	--------------------------	-----	--------------------------	----	--

Interior: Estimated Cost:	\$	4,250.00
----------------------------------	----	-----------------

Total Essential Repairs, Exterior, and Interior Cost:*	\$	22,200.00
---	----	------------------

*average contracted cost. Actual costs may vary. Self help will reduce the amount.

Inspected by: Nikolas Stoehr

Date: 2/12/2019

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start.

Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants *may* be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants *may* be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located at 841 N. Broadway, 1st Floor.