



Certificate of Appropriateness

LIVING WITH HISTORY

Milwaukee Historic Preservation Commission/809 N. Broadway/PO Box 324/Milwaukee, WI 53201-0324/414-286-5712

Property 2650 N. WAHL AV. (Lion Bridges in Lake Park)
Description of work Restore the bridges and restoration of the concrete bollards and overlook.
Date issued 10/9/2009 PTS ID 49802 COA, Lion Bridge Restoration

In accordance with the provisions of Section 308-81(9) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:


Sandblast all metal, repair and repaint. Tuckpoint and clean stone abutments as needed and install new matching stone in places where stone is deteriorated beyond repair. The bridge railings will be restored to the original condition with a metal finial in each grid. Extensive renovation work will also be done on the truss work that supports the bridge deck. The original trusses will be preserved and a new concrete deck will be installed on top. Landscaping around the plateau from the crest to approximately 40' down the slope. Coir wattles will be placed along the slope to help prevent erosion. Realign and/or replace tipped or missing bollards with similar materials and based on the original bollard plans. Repair and/or replace the existing deteriorated concrete overlook with similar materials that match the original overlook plans. Replace the chain between the bollards and the overlook. All work shall coincide with submitted and attached drawings and photos.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Carlen Hatala of the Historic Preservation staff as follows: Phone: (414) 286-5722 Fax: (414) 286-0232 E-mail: chatal@milwaukee.gov.


If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.mkedcd.org/build, or call (414) 286-8210 or 8211.

Carlen Hatala
City of Milwaukee Historic Preservation


Copies to: Development Center, Ald. Nik Kovac, Contractor, Inspector Jim Friedrichs (286-5982)



Historic Postcard image of the cannon overlook and bollards, c.1909



Existing deteriorated remains of the cannon overlook



PROJECT NO: 0000-20-40

HWY: S. LION PED. BRIDGE

COUNTY: MILWAUKEE

CENTER PLATEAU SITE PLAN

SHEET

E

FILE NAME : X:\13220-20\00002\TECH\CADD\050208.dwg


PLOT DATE : 10/6/2009

PLOT BY : 1047JJB


PLOT NAME :

PLOT SCALE : 50.00' = 1"

WISDOT/DADS SHEET 42



South Bridge
Abutments



South abutment



Southwest wingwall

**REPAIR OR REPLACE
DAMAGED STONE AND
TUCKPOINT**

South Bridge

INSTALL NEW FINIALS



Elevation

**SANDBLAST, REPAIR,
AND PAINT ALL METAL**



View along deck

REPLACE CONCRETE DECK