

Sherman Blvd Hist. Dist.



Certificate of Appropriateness

LIVING WITH HISTORY

Milwaukee Historic Preservation Commission/809 N. Broadway/PO Box 324/Milwaukee, WI 53201-0324/414-286-5712

Property 2803 N. SHERMAN BL.
Description of work Rebuild chimney from roofline, install stainless steel lining system in 2 main flues. Original face brick to be hand cleaned and re-laid using "N" type mortar and the addition of lime.
Date issued 6/20/2008

PTS ID 51577 Rebuild chimney from roofline

In accordance with the provisions of Section 308-81(9) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

All mortar joints to match original in terms of color, finish, texture and joint width. Original face brick will be carefully salvaged and reinstalled.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact Paul Jakubovich of the Historic Preservation staff as follows: Phone: (414) 286-5712 Fax: (414) 286-0232 E-mail: pjakub@milwaukee.gov.

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, www.mkedcd.org/build, or call (414) 286-8210 or 8211.

Paul Jakubovich
City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. Willie Wade, Inspector Keith Spruce (286-8160)