



# Certificate of Appropriateness

**LIVING WITH HISTORY**

Milwaukee Historic Preservation Commission/809 N. Broadway/PO Box 324/Milwaukee, WI 53201-0324/414-286-5712

**Property**

2814 N. SHERMAN BL.

**Description of work**

-Ramp already built w/o proper COA. Gaps between balusters in balustrade are too large, must add additional centered 1 X 4 posts in all gaps. All railing components have to painted. Existing ramp flooring can remain unpainted.

**Date issued**

11/3/2008

PTS ID 54866 Front Door Ramp

In accordance with the provisions of Section 308-81(9) of the Milwaukee Code of Ordinances, the Milwaukee Historic Preservation Commission has issued a certificate of appropriateness for the work listed above. The work was found to be consistent with preservation guidelines. The following conditions apply to this certificate of appropriateness:

All work to be done according to attached drawings and images.

All work must be done in a craftsman-like manner, and must be completed within one year of the date this certificate was issued. Staff must approve any changes or additions to this certificate before work begins. Work that is not completed in accordance with this certificate may be subject to correction orders or citations. If you require technical assistance, please contact of the Historic Preservation staff as follows: .

If permits are required, you are responsible for obtaining them from the Milwaukee Development Center. If you have questions about permit requirements, please consult the Development Center's web site, [www.mkedcd.org/build](http://www.mkedcd.org/build), or call (414) 286-8210 or 8311.

Paul Jakubovich  
City of Milwaukee Historic Preservation Staff

Copies to: Development Center, Ald. Willie Wade, Inspector Joel Walloch (286-8160)

**Gaps too large, insert additional balusters on center**

**All railing components to be painted**

