



Erosion Control Check Sheet

Permit & Development Center

809 N. Broadway, Milwaukee, WI 53202 | (414) 286-8211 | milwaukee.gov/permits | DevelopmentCenterInfo@milwaukee.gov

Property Address: _____

Inspector: _____

Permit Number: _____

	Date	Date	Date	Date	Date	Date	Date	Date	Date	Date
Silt Fence										
Fence fabric overlapped										
Based trenched 4"										
Maximum 8' post spacing										
Fabric properly installed										
Fence ends turned upward										
Maximum 9" storage height										
Tracking Pad										
Pad in place										
Pad adequately maintained										
Pad meets minimum standards										
No street tracking										
Inlet Protection										
Inlet protection in place										
Inlet protection maintained										
Inlet protection area swept										
Straw Bales										
Bales properly installed/staked										
Bales in good condition										
Ground Cover										
Ground cover in place										
Ground cover maintained										
Storm Event										
Next day sediment cleanup										
All erosion control checked										